



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
 - - - ASME SECTION XI CLASS 2 PIPING
 - ASME SECTION XI CLASS 3 PIPING
 - NON-151 NUCLEAR CLASS AND HSC CLASS
 - PRESSURE BOUNDARY EXTENSION
 - REFERENCE & CONTINUITY
 - D - D - HVAC DUCT
 - A ANCHOR
 - CS CONSTANT SPRING HANGER
 - VS VARIABLE SPRING HANGER
 - HS HYDRAULIC SNUBBER
 - MS MECHANICAL SNUBBER
 - N NON-WELDED SUPPORT ATTACHMENT
 - W WELDED INTEGRAL SUPPORT ATTACHMENT
 - R RIGID SUPPORT
 - T SWAY STRUT
 - SW SHOP WELD
 - FW FIELD WELD
 - LW LONGITUDINAL WELD
 - WOL WELDLET
 - IS1 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- NOTES:**
1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE) 2WS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.
 2. WELDED TEES HAVE THEIR SEAM WELD LOCATION 30° OFF CENTERLINE OF THE RUN.
- GENERAL NOTE**
- DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.
- REFERENCE DRAWINGS:**
- IS102-0338 DECAY HEAT TRAIN 1
 - IS102-033C DECAY HEAT TRAIN 2

1	INC. DCH IS1M2-233F-12 FOR RFA 93-0254	SBW	FS	AC	—	
2	INC. DCH IS1M2-233F-10 FOR RFA 92-0232				"INITIALS ON FILE"	
3	INC. DCH IS1M2-233F-2 & 3 PER DCH 91-001				"INITIALS ON FILE"	
4	ISSUED FOR SECOND YEAR ISI PROGRAM	CB	MCV	WT	MCP	DWH

SCALE: N.T.S. DESIGNED: DRAWN: CB DATE:

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1

INSERVICE INSPECTION ISOMETRIC
LOW PRESSURE INJECTION SYSTEM
AUXILIARY BUILDING

CALCULATED BY: REV.:

ISIM2-233F 3

14 3/4" x 11" SIZE

D-33

11-3-93 OPERATOR *[Signature]* 30X