



- LEGEND**
- ASME SECTION XI CLASS 1 PIPING
  - ASME SECTION XI CLASS 2 PIPING
  - ASME SECTION XI CLASS 3 PIPING
  - NON-ISI NUCLEAR CLASS AND HSC CLASS
  - PRESSURE BOUNDARY EXTENSION
  - REFERENCE B CONTINUITY
  - HVAC DUCT
- NOTES:**
1. MULTIPLE SNAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)
  2. THE SPENT FUEL POOL COOLING LINE 2 1/2" HCC-10 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10C 1220. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
  3. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE ISI BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

**GENERAL NOTE:**  
DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

- REFERENCE DRAWINGS:**
- IS102-033B DECAY HEAT TRAIN 1
  - IS102-035 SPENT FUEL POOL COOLING SYSTEM

INC DCN IS102-235A-5 FOR DCR 91-0011		JON	
ISSUED FOR SECOND YEAR ISI PROGRAM		CB EFB LLC MOP ECC	
NO.	DATE	REVISIONS	BY
SCALE: N.T.S. DESIGNER: [Signature] DRAWN: CB DATE: [Date]			
<b>DAVIS-BESSE NUCLEAR POWER STATION</b>			
<b>UNIT NO. 1</b>			
INSERVICE INSPECTION ISOMETRIC			
SPENT FUEL POOL COOLING SYSTEM			
AUXILIARY BUILDING-AREA 7			
ISIM2-235A		1	
SHEET 4		P-47	