



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-151 NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE BOUNDARY CONTINUITY
- HVAC DUCT
- ANCHOR
- CONSTANT SPRING HANGER
- VARIABLE SPRING HANGER
- HYDRAULIC SNUBBER
- MECHANICAL SNUBBER
- NON-WELDED SUPPORT ATTACHMENT
- WELDED INTEGRAL SUPPORT ATTACHMENT
- RIGID SUPPORT
- SWAY STRUT
- SHOP WELD
- FIELD WELD
- LONGITUDINAL WELD
- WELDOLET
- 151 ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

NOTES:

1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2NHS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE.)
2. THE SPENT FUEL POOL COOLING LINE 4"-HCB-25, 4"-HCC-29, 10"-HCB-6 & 10"-HCB-24 WELDS AND SUPPORTS ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER 10D.1220. THE WELDS AND SUPPORTS SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
3. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE 151 BOUNDARY, ARE SHOWN FOR REFERENCE AND CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.
4. CHECK VALVE SF90 WAS ADDED UNDER FOR 77-0076 TO SUPPORT INSTALLATION OF A SUMP PUMP IN THE TRANSFER PIT. NO FURTHER WORK WILL BE DONE. ADDITIONAL PIPING ATTACHED AT THIS FLANGE MAY BE LEFT IN PLACE OR REMOVED AS NECESSARY.

GENERAL NOTE:

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

15102-035 SPENT FUEL POOL COOLING SYSTEM

NO.	DATE	REVISION	BY	CHECKED	APP.
1	11/10/02	ISSUED FOR SECOND 10 YEAR ISI PROGRAM			
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					

DAVIS-BESSE NUCLEAR POWER STATION
 UNIT NO. 1
 INSERVICE INSPECTION ISOMETRIC
 SPENT FUEL POOL COOLING SYSTEM
 AUXILIARY BUILDING AREA B
 ISIM2-235B
 (SHEET 2)

D-49