



**LEGEND**

- ASME SECTION XI CLASS 1 PIPING
- - - ASME SECTION XI CLASS 2 PIPING
- · - · ASME SECTION XI CLASS 3 PIPING
- · — · NON-ISI NUCLEAR CLASS AND HSC CLASS
- · — · PRESSURE BOUNDARY EXTENSION
- · — · REFERENCE & CONTINUITY
- D - D - HVAC DUCT
- A ANCHOR
- CS CONSTANT SPRING HANGER
- VS VARIABLE SPRING HANGER
- HS HYDRAULIC SNUBBER
- MS MECHANICAL SNUBBER
- N NON-WELDED SUPPORT ATTACHMENT
- W WELDED INTEGRAL SUPPORT ATTACHMENT
- R RIGID SUPPORT
- T SWAY STRUT
- SW SHOP WELD
- FW FIELD WELD
- LW LONGITUDINAL WELD
- WOL WELDOLET
- ⊠ ISI ITEM NUMBER DESIGNATION US... IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

**NOTES:**

1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2HS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
2. THERE ARE NO SPOOL NUMBERS FOR PIPING ON THIS DRAWING.
3. THE SUPPORTS ON THE MOTOR DRIVEN FEED PUMP LINE 6"-EBD-14 ARE WITHIN THE ISI EXAMINATION BOUNDARY. THE PIPING WELDS IN THIS LINE ARE SHOWN FOR REFERENCE PURPOSES ONLY. THESE WELDS MAY NOT BE REPRESENTED IN THE ACTUAL AS-BUILT CONDITION.

**GENERAL NOTES:**

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

**REFERENCE DRAWINGS:**

- IS102-0060 AUXILIARY FEEDWATER SYSTEM
- IS102-0078 STEAM GENERATOR SECONDARY SYSTEM
- HL-1174 HANGER LOCATION DRAWING SMT.2 OF 2 FOR FCR 85-025

	INC DCN IS1M2-2060-1 FOR DCN 91-0011	JOB	DATE		
ISSUED FOR SECOND 10 YEAR ISI PROGRAM					
NO.	DATE	REVISED	BY	CHKD	ENGR
SCALE: N.T.S.    DESIGNED:    DRAWN: CB    DATE:					
<b>DAVIS-BESSE NUCLEAR POWER STATION</b>					
UNIT NO. 1					
INSERVICE INSPECTION ISOMETRIC CONDENSATE SYSTEM					
MOTOR DRIVEN FEED PUMP P-241 DISCHARGE					
DRAWING NO. IS1M2-2060					
1					

D-110

