



LEGEND

- ASME SECTION XI CLASS 1 PIPING
- - - ASME SECTION XI CLASS 2 PIPING
- ASME SECTION XI CLASS 3 PIPING
- NON-ISI NUCLEAR CLASS AND HSC CLASS
- PRESSURE BOUNDARY EXTENSION
- REFERENCE & CONTINUITY
- D - D - HYAC DUCT
- A ANCHOR
- CS CONSTANT SPRING HANGER
- VS VARIABLE SPRING HANGER
- HS HYDRAULIC SNUBBER
- MS MECHANICAL SNUBBER
- H NON-WELDED SUPPORT ATTACHMENT
- W WELDED INTEGRAL SUPPORT ATTACHMENT
- R RIGID SUPPORT
- T SWAY STRUT
- SW SHOP WELD
- FW FIELD WELD
- LW LONGITUDINAL WELD
- WOL WELDLET
- ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

NOTES:

1. MULTIPLE SWAY STRUTS, SPRING SUPPORTS OR SNUBBERS IN A SINGLE PIPING SUPPORT ARE SHOWN BY A NUMBER BEFORE THE SUPPORT TYPE. (EXAMPLE: 2MS - TWO HYDRAULIC TYPE SNUBBERS THAT ARE NOT WELDED INTEGRAL TO THE PIPE).
2. RING HEADER SHOWN IN DETAIL "2" SHALL BE INSPECTED PER ASME SECTION XI, IWC CLASS 2.
3. PIPE WHIP RESTRAINTS ARE SHOWN FOR INFORMATION ONLY AND ARE NOT SUBJECT TO INSPECTION UNDER ASME SECTION XI. MEV 1 AND MEV 4 HAVE BEEN ABANDONED IN PLACE.
4. THE FEEDWATER HEADER RISER TUBES ARE EXEMPT FROM INSERVICE EXAMINATION REQUIREMENTS PER IWC 1200.
5. PIPING SYSTEMS ON THIS DRAWING WHICH ARE OUTSIDE OF THE ISI BOUNDARY ARE SHOWN FOR REFERENCE & CONTINUITY PURPOSES ONLY. THE CONFIGURATION SHOWN MAY NOT REPRESENT THE ACTUAL AS-BUILT CONDITION.

GENERAL NOTE

DIMENSIONS SHOWN ON THIS DRAWING ARE TO BE USED FOR APPROXIMATE LOCATION ONLY. USE DESIGN DRAWINGS FOR DIMENSIONAL VERIFICATION.

REFERENCE DRAWINGS:

- 15102-007A STEAM GENERATOR SECONDARY SYSTEM
- 15102-007B STEAM GENERATOR SECONDARY SYSTEM
- 7749-C-612 CONTAINMENT BUILDING MAIN FEEDWATER SEISMIC RESTRAINT DETAILS, SHEET #1.
- 7749-C-613 CONTAINMENT BUILDING MAIN FEEDWATER SEISMIC RESTRAINT DETAILS, SHEET #2.
- BARCOCK & WILCOX DRAWING 151918E, ERECTION ASSEMBLY-FEEDWATER HEADER AND NOZZLES (STEAM GENERATOR).
- BARCOCK & WILCOX DRAWING 151922, FEEDWATER INLET AND HEADER.

REV.	DATE	REVISIONS	BY	CHKD.	APP. AUTH.
DRAWN N.T.S. DESIGNED CHECKED CB TITLE					
DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1 <small>THE FULBROOK DESIGN COMPANY</small>					
INSERVICE INSPECTION ISOMETRIC MAIN FEEDWATER SYSTEM AUXILIARY AND CONTAINMENT BUILDINGS					
					14 34X44 1/4" SIZE
ISIM2-207C (SHEET 2)					2

D-113

6-17-93 OPERATOR: [Signature] 30X