



INFO. NOTE:  
 (REMOVE AT NEXT UPDATE)  
 REVISION CHANGE IN THE CLOUDED  
 AREA WAS FOR COLORIZING THE  
 LINE CLASS CODES

**LEGEND**

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE & CONTINUITY
- 0-0-0 HVAC DUCT

- ISIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- ASME SECTION XI CLASS CHANGE
- ISI PROGRAM BOUNDARY

- NOTES:**
- DELETED
  - FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE IS102-001.
  - FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
  - UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 3/4" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.

D-123

1	ISID DCN ISID2-010C-2 PER DDR 00-1766	SBW			
2	ISID DCN ISID2-010C-1 FOR DEC 91-001		INITIAL	DN	FILE
3	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	CB	MTF	JBC	JDE MGP ECC
NO.	DATE	REVISION	BY	CHK'D	DATE
SCALE N.T.S.					
DESIGNED					
DRAWN CB					
DATE					
<b>DAVIS-BESSE NUCLEAR POWER STATION</b>					
<b>UNIT NO. 1</b>					
THE EDISON COMPANY					
<b>INSERVICE INSPECTION DIAGRAM</b>					
<b>MAKE-UP WATER TREATMENT SYSTEM</b>					
DRAWING NO.			REV.		
ISID2-010C			2		