RC=CEL:([55,100]FORMATS.CEL AC=E7749

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

LEGEND

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE & CONTINUITY
- D HVAC DUCT

ISIM2- REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.

RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.

REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.

1/2 ASME SECTION XI CLASS CHANGE

2 ISI PROGRAM BOUNDARY

NOTES:

1. DELETED
2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
3. FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE 3/4" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.
5. UNLESS OTHERWISE NOTED, ALL DAMPERS ARE NORMALLY OPEN.

STATION VENT

HYDROGEN RECOMBINER

EMERGENCY VENT SYSTEM FAN & FILTER UNITS

H_2 PURGE SYSTEM FILTER UNIT PACKAGE

TOP OF SECONDARY SHIELD WALLS

CONTAINMENT RECIRCULATION FAN C56-1, NO. 1-1

CONTAINMENT RECIRCULATION FAN C56-2, NO. 1-2

HYDROGEN DILUTION SYSTEM BLOWERS C62-1, NO.1-1 C62-2, NO.1-2

MAKE-UP PUMP ROOM 228

MECH. PENT. ROOM NO.2 236

MECH. PENT. ROOM NO.4 314

ELEC. PENT. ROOM NO.1 402

MECHANICAL PENET. ROOM NO.3 303

MECHANICAL PENET. ROOM NO.1 208

C.V. SPRAY N.P. INJ. & DECAY HT. PUMPS 105

C.V. SPRAY N.P. INJ. & DECAY HT. PUMPS 115

DECAY HEAT COOLERS 113

ACCESS TUNNEL

REACTOR

REACTOR CAVITY

INCORE TUNNEL

SHIELD BUILDING ANNULUS UNIT HEATERS NO.1-1 THRU 1-12

3	/ /	INC. DCN ISID2-029D-6 PER DDR 00-1766	SBW						
2	02/16/96	INC. DCN'S ISID2-029D-2 FOR RFA 93-0473, ISID2-029D-3 FOR DCR 93-0063, ISID2-029D-4 FOR DCR 93-0057 AND ISID2-029D-5 FOR DCR 93-0053	INITIALS ON FILE						
1	12/19/91	INC. DCN ISID2-029D-1 FOR DCR 91-0011	INITIALS ON FILE						
0	02/23/90	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	CB	JBG JJS	JDE	MGP	ECC		
NO.	DATE	REVISIONS	BY	CH'K	ENGR. SUPV.	ENGR. SUPV.	ENGR. MGR.		

SCALE N.T.S. DESIGNED DRAWN CB DATE

DAVIS-BESSE NUCLEAR POWER STATION UNIT NO. 1 0
THE TOLEDO EDISON COMPANY

INSERVICE INSPECTION DIAGRAM
CONTAINMENT AND PENETRATION ROOMS SHEET 3

DRAWING NO. ISID2-029D REV. 3

D-132

DB 08-10-00 DFN= r:\ISID\2SID029D.DGN LEVELS 1234567890123456789012345678901234567890123456789012345678901234567890123456789012 14 34X44 SIZE PSC= 11 1