RC=CEL:[55,100]FORMATS.CEL AC=ESTD

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES

INFO. NOTE:
(REMOVE AT NEXT UPDATE)
REVISION CHANGE IN THE CLOUDED AREA WAS FOR COLORIZING THE LINE CLASS CODES(REF. DCN 3)

LEGEND 3

- ASME SECTION XI CLASS 1 PIPING (RED)
- ASME SECTION XI CLASS 2 PIPING (BLUE)
- ASME SECTION XI CLASS 3 PIPING (GREEN)
- REFERENCE 8 CONTINUITY
- D=D= HVAC DUCT

- ISIM2- — REFERENCE TO THE PIPING ISOMETRIC DRAWING FOR DETAILS ON THE PIPING CONFIGURATION, AND THE LOCATION AND IDENTIFICATION OF WELDS AND SUPPORTS.
- RESERVED FOR SPECIAL ISI REQUIREMENTS. (MAY BE) ACCOMPANIED BY SPECIFIC NOTES.
- REFERENCE TO THE ISI ITEM NUMBER DESIGNATION USED IN THE FIRST 10 YEAR INSERVICE INSPECTION INTERVAL.
- 1/2 — ASME SECTION XI CLASS CHANGE
- 2 — ISI PROGRAM BOUNDARY

NOTES: 3

1. DELETED
2. FOR ISI BOUNDARY DIAGRAM INDEX SHEET AND GENERAL NOTES, SEE ISID2-001.
3. FOR PIPING SYMBOLS AND P & ID INDEX, SEE DRAWING M-001.
4. UNLESS OTHERWISE NOTED, ALL VENT CONNECTIONS ARE ¾" AND DRAIN CONNECTIONS ARE 1". LINE IDENTIFICATION IS THE SAME AS THE HEADER.

SERVICE WATER PUMP 1-1 — SERV. WTR. STRN. 1-1 — SERVICE WATER PUMP 1-3 — SERV. WTR. STRN. 1-3 — SERVICE WATER PUMP 1-2 — SERV. WTR. STRN. 1-2

D-148

NO.	DATE	REVISIONS	BY	CH'K	ENGR.	ENGR. SUPV.	OPN. SUPV.
3	//	INC. DCN ISID2-041A-3 PER DDR 00-1766 & DCN ISID2-041A-4 PER DDR 00-1860	SBW				
2	02/22/96	INC. DCN ISID2-041A-2 PER DDR 95-2486	INITIALS ON FILE				
1	12/10/91	INC. DCN ISID2-041A-1 FOR DCR 91-0011	INITIALS ON FILE				
0	4/22/90	ISSUED FOR SECOND 10 YEAR ISI PROGRAM	BLN	MTF JBG	JDE	MGP	ECC

SCALE N.T.S. | DESIGNED | DRAWN BLN | DATE

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO. 1 — THE TOLEDO EDISON COMPANY — 0

INSERVICE INSPECTION DIAGRAM

SERVICE WATER PUMPS AND SECONDARY SERVICE WATER SYSTEM

DRAWING NO. ISID2-041A — REV. 3

DD 08-10-00 | DFN= r:/ISID /2SID041A.DGN | LEVELS 1234567890123456789012345678901234567890123456789012345678901234567 | 14 | 34X44 C SIZE | PSC= 111