

December 12, 1996

MEMORANDUM TO: James M. Taylor  
Executive Director for Operations

FROM: John C. Hoyle, Secretary /s/

SUBJECT: STAFF REQUIREMENTS - BRIEFING ON SPENT FUEL  
POOL STUDY, 2:00 P.M., THURSDAY, NOVEMBER 14,  
1996, COMMISSIONERS' CONFERENCE ROOM, ONE  
WHITE FLINT NORTH, ROCKVILLE, MARYLAND (OPEN  
TO PUBLIC ATTENDANCE)

The Commission was briefed by the NRC staff on the spent fuel pool study. The staff should provide an explanation for the apparent discrepancy of the curve of "hours to boil" versus "days to offload" for the Outage 3 data on Slide 13 (i.e., 29 hours to boil seems to be too high when compared to the hours since offload values for the other outages.)

(EDO)

(SECY Suspense: 1/10/97)

There were no other requirements identified for staff action.

cc: Chairman Jackson  
Commissioner Rogers  
Commissioner Dicus  
Commissioner Diaz  
Commissioner McGaffigan  
OGC  
OCA  
OIG  
Office Directors, Regions, ACRS, ACNW, ASLBP (via E-Mail)  
PDR - Advance  
DCS - P1-24