



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



October 9, 2000


US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for September, 2000
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of September, 2000.

Very truly yours,


Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 8C2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

JE24

OPERATING DATA REPORT

-1-

50-244

October 9, 2000

COMPLETED BY: John V. Walden

John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes:
2. Reporting Period: September, 2000
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

| | This Month | Yr.-to-Date | Cumulative** |
|--|-----------------|------------------|-------------------|
| 5. Number of hours Reactor Was Critical | <u>413.1</u> | <u>6268.1</u> | <u>220482.0</u> |
| 6. Hours Generator On-line | <u>412.6</u> | <u>6250.8</u> | <u>217394.7</u> |
| 7. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>8.5 *</u> |
| 8. Net Electrical Energy Generated (MWH) | <u>168009.0</u> | <u>2975126.6</u> | <u>98360262.0</u> |

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
 UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
 DATE: October 9, 2000
 COMPLETED BY: John V. Walden
 TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: September, 2000
 (Month/Year)

| NO. | DATE | TYPE | DURATION (HOURS) | REASON ⁽¹⁾ | METHOD OF SHUTTING DOWN ⁽²⁾ | CAUSE/CORRECTIVE ACTIONS |
|-----|--------|---------------------------|---------------------|-----------------------|--|--------------------------|
| | | F: FORCED S: SCHEDULED | | | | COMMENTS |
| 2 | 000918 | S | 307.4 | C | 1 | |

SUMMARY:

Reactor power decreased from 94% to 76% from September 1, 2000 to September 17, 2000 at 2400 due to end of fuel cycle 28 coastdown. A power reduction for the refueling shutdown was initiated and the unit was taken off line at 0439 on September 18, 2000. The unit remained in refueling shutdown for the remainder of the month.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)