

September 20, 2000

Mr. A. Alan Blind
Vice President, Nuclear Power
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, NY 10511

SUBJECT: MODIFICATIONS TO EMERGENCY ACTION LEVELS, INDIAN POINT
NUCLEAR GENERATING UNIT NO. 2 (TAC NO. MA6814)

Dear Mr. Blind:

By letter dated October 8, 1999, as supplemented on December 16, 1999, and July 21, 2000, Consolidated Edison Company of New York, Inc. (ConEd) submitted to the U.S. Nuclear Regulatory Commission (NRC) proposed modifications to the Emergency Action Levels (EALs) for the Indian Point Nuclear Generating Unit No. 2. Specifically, ConEd requested the NRC to approve proposed modifications to (1) EALs 6.1.1, "Unusual Event," and 6.1.3, "Alert," for the loss of alternating current power sources, and (2) EALs 6.2.1, "Unusual Event," and 6.2.2, "Site Area Emergency," for the loss of direct current power sources. As detailed in the October 8 submittal, ConEd indicated that the proposed modifications to the wording of these EALs was intended to clarify the plant-specific wording of the respective EALs to more closely reflect applicable initiating conditions as provided by the examples given in the Nuclear Management and Resources Council (NUMARC; now the Nuclear Energy Institute) guidance document, NUMARC/NESP-007, "Methodology for Development of Emergency Action Levels," Revision 2.

The NRC staff finds that the EALs, as reworded, remain consistent with the guidance, and therefore, continue to meet the requirements of 10 CFR 50.47(b) and Appendix E to 10 CFR Part 50. Therefore, the NRC staff finds the proposed changes to be acceptable.

This completes our action for TAC No. MA6814. If you have any questions, please contact me at 301-415-1457.

Sincerely,
/RA/

Patrick D. Milano, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-247
cc: See next page

DISTRIBUTION:

PUBLIC
PDI-1 Reading File
E. Adensam

M. Gamberoni
K. Gibson
P. Milano
S. Little

D. Barrs
M. Oprendeck, RGN-I
OGC
ACRS

Accession Number: ML003750176

OFFICE	PM:PDI-1	LA:PDI-1	SC:IOLB	SC:PDI-1		
NAME	PMilano	Slittle	KGibson	MGamberoni		
DATE	9/14/00	9/15/00	9/15/00	9/19/00		

Official Record Copy

Indian Point Nuclear Generating Station
Unit 2

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. F. William Valentino, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Ave. Extension
Albany, NY 12203-6399

Mr. John McCann
Manager of Nuclear Safety and
Licensing
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, NY 10511

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P.O. Box 38
Buchanan, NY 10511

Mr. Brent L. Brandenburg
Assistant General Counsel
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, NY 10003

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Ms. Charlene D. Faison, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Mr. Thomas Rose
Secretary - NFSC
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, NY 10511

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223