Entergy

**Entergy Operations, Inc.**
River Bend Station
5485 U.S. Highway 61
P. O. Box 220
St. Francisville, LA 70775
Tel 225 336 6225
Fax 225 635 5068

**Rick J. King**
Director
Nuclear Safety Assurance

October 13, 2000

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Subject: Monthly Operating Report
River Bend Station
Docket No. 50-458
License No. NPF-47

File No.: G9.5, G4.25

RBG-45511
RBF1-00-0224

Ladies and Gentlemen:

In accordance with River Bend Station Technical Specification 5.6.4, enclosed is the Monthly Operating Report for September 2000.

Sincerely,

RJK/dlm
enclosure

IE24

cc: U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
P. O. Box 1050
St. Francisville, LA 70775

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Mr. Jim Calloway
Public Utility Commission of Texas
1701 N. Congress Ave.
Austin, TX 78711-3326

Dottie Sherman
American Nuclear Insurers
29 South Main Street
West Hartford, CT 06107

DOCKET NO. 50/458
RIVER BEND STATION
DATE October 13, 2000
COMPLETED BY Douglas L. Myers
TITLE Sr. Licensing Specialist
TELEPHONE 225-381-4590



## OPERATING STATUS

1. REPORTING PERIOD: September 2000
2. MAXIMUM DEPENDABLE CAPACITY (MWe-Net): 936
3. DESIGN ELECTRICAL RATING (MWe-Net): 936

| | MONTH | YEAR TO DATE | CUMULATIVE |
|---|---|---|---|
| 4. NUMBER OF HOURS REACTOR WAS CRITICAL | 720.0 | 5667.1 | 100966.7 |
| 5. HOURS GENERATOR ON LINE | 720.0 | 5586.9 | 97434.3 |
| 6. UNIT RESERVE SHUTDOWN HOURS | 0 | 0 | 0 |
| 7. NET ELECTRICAL ENERGY GENERATED (MWH) | 674,359 | 5,166,108 | 85,594,203 |

## UNIT SHUTDOWNS

| NUMBER | DATE | TYPE | DURATION | SHUTDOWN METHOD | REASON | CAUSE / CORRECTIVE ACTIONS |
|---|---|---|---|---|---|---|

**LEGEND:**

**TYPE:** F - Forced; S - Scheduled

**SHUTDOWN METHOD:**
1 - Manual
2 - Manual trip/scram
3 - Automatic trip/scram
4 - Continuation
5 - Other (explain)

**REASON:**
A - Equipment failure (explain)
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator training / License exam
F - Administrative
G - Operational error (explain)
H - Other (explain)

**NOTES:**

1. No challenges to the reactor safety-relief valves occurred in September.
2. The unit was not shutdown during the month of September.

Douglas L. Myers

Douglas L. Myers