Mr. M. S. Tuckman Executive Vice President Nuclear Generation Duke Energy Corporation 526 South Church Street P. O. Box 1006 Charlotte, NC 28201-1006

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 RE: REQUEST FOR ADDITIONAL INFORMATION (TAC NOS. MA9886, MA9887, AND MA9888)

Dear Mr. Tuckman:

By letter dated August 28, 2000, you submitted a request for NRC review and approval of the methodology that will be used for the reactor coolant loop re-analysis as part of the steam generator replacement project at the Oconee Nuclear Station, Units 1, 2, and 3. In the submittal you indicated that breaks in large bore primary piping have not been considered because the NRC has approved Topical Report BAW-1847, Rev. 1. In order to complete its review, the staff requests that you provide the information shown in the enclosure regarding application of the topical report. This request has been discussed with Mr. Robert Sharpe of you staff and a target date of February 1, 2001, established to respond to this request by either supplying the information or describing a commitment to supply it.

Sincerely,

/RA/

David E. LaBarge, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Request for Additional Information

cc w/encl: See next page

Mr. M. S. Tuckman Executive Vice President Nuclear Generation Duke Energy Corporation 526 South Church Street P. O. Box 1006 Charlotte, NC 28201-1006 October 23, 2000 <u>Distribution</u>: PUBLIC LBerry PDII-1 Reading RidsOgcRp RidsNrrDlpm RidsAcrsAcnwMailCenter RidsNrrDlpmLpdii1 RidsRgn2MailCenter CHawes (paper copy)PYChen DLaBarge (paper copy)SSheng

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 RE: REQUEST FOR ADDITIONAL INFORMATION (TAC NOS. MA9886, MA9887, AND MA9888)

Dear Mr. Tuckman:

By letter dated August 28, 2000, you submitted a request for NRC review and approval of the methodology that will be used for the reactor coolant loop re-analysis as part of the steam generator replacement project at the Oconee Nuclear Station, Units 1, 2, and 3. In the submittal you indicated that breaks in large bore primary piping have not been considered because the NRC has approved Topical Report BAW-1847, Rev. 1. In order to complete its review, the staff requests that you provide the information shown in the enclosure regarding application of the topical report. This request has been discussed with Mr. Robert Sharpe of you staff and a target date of February 1, 2001, established to respond to this request by either supplying the information or describing a commitment to supply it.

Sincerely,

/RA/

David E. LaBarge, Senior Project Manager, Section 1 Project Directorate II Division of Licensing Project Management Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Request for Additional Information

cc w/encl: See next page DOCUMENT NAME: Accession #MI 003762023

OFFICE	PDII-1/PM	PDII-1/LA	PDII-1/SC
NAME	DLaBarge:mw	CHawes	REmch
DATE	10/18/00	10/18/00	10/20/00

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION REGARDING

DUKE ENERGY CORPORATION'S RE-ANALYSIS OF

THE REACTOR COOLANT LOOP IN SUPPORT OF

STEAM GENERATOR REPLACEMENT

AT OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3

Per your submittal, you indicated that breaks in large bore primary piping has not been considered because the NRC has approved Topical Report BAW-1847, Rev. 1. Provide the following information to demonstrate that the analyses and results of this topical report still bounds the plant-specific applications at the Oconee Nuclear Station, Units 1, 2, and 3 after the steam generator replacement:

- 1. Assess the impact on applicability of BAW-1847, Rev. 1 to the Oconee Nuclear Station, Units 1, 2, and 3 due to any change of loading (dead weight, transients, OBE, and SSE) caused by the steam generator replacement.
- Assess the impact on applicability of BAW-1847, Rev. 1 to Oconee, Units 1, 2, and 3 due to any piping material (base metal and weld) degradation and aging that might have occurred during the past 15 years of operation of the Oconee Nuclear Station, Units 1, 2, and 3. This evaluation should include the change of the pipe size (dimension) and the change of material properties such as the flow stress, Ramberg-Osgood parameters, and the fracture toughness (J or K_{ic}) due to degradation and aging.
- 3. Summarize your effort in tables similar to Table 4-11 and Table 4-12 of BAW-1847, Rev. 1. Remember that the staff is not asking you to repeat the analyses of BAW-1847, Rev. 1, but to apply your engineering judgement at every critical step to estimate the final safety factors for the primary piping of the Oconee Nuclear Station, Units 1, 2, and 3.

Oconee Nuclear Station

cc: Ms. Lisa F. Vaughn Legal Department (PBO5E) Duke Energy Corporation 422 South Church Street Charlotte, North Carolina 28201-1006

Anne W. Cottingham, Esquire Winston and Strawn 1400 L Street, NW Washington, DC 20005

Mr. Rick N. Edwards Framatome Technologies Suite 525 1700 Rockville Pike Rockville, Maryland 20852-1631

Manager, LIS NUS Corporation 2650 McCormick Drive, 3rd Floor Clearwater, Florida 34619-1035

Senior Resident Inspector U. S. Nuclear Regulatory Commission 7812B Rochester Highway Seneca, South Carolina 29672

Virgil R. Autry, Director Division of Radioactive Waste Management Bureau of Land and Waste Management Department of Health and Environmental Control 2600 Bull Street Columbia, South Carolina 29201-1708 Mr. L. E. Nicholson Compliance Manager Duke Energy Corporation Oconee Nuclear Site 7800 Rochester Highway Seneca, South Carolina 29672

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. C. Jeffrey Thomas Manager - Nuclear Regulatory Licensing Duke Energy Corporation 526 South Church Street Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director Division of Radiation Protection North Carolina Department of Environment, Health, and Natural Resources 3825 Barrett Drive Raleigh, North Carolina 27609-7721

Mr. Steven P. Shaver Senior Sales Engineer Westinghouse Electric Company 5929 Carnegie Blvd. Suite 500 Charlotte, North Carolina 28209