



October 12, 2000
NMP2L 1988

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Docket No. 50-410
Licensee Event Report 00-12, Retraction

Gentlemen:

This letter is to inform the NRC that Niagara Mohawk Power Corporation is retracting Licensee Event Report 00-12, "Violation of Technical Specifications Due to Potential Buildup of Condensate in the Containment Monitoring System Hydrogen-Oxygen Analyzer Sample Return Line," which had been reported in accordance with 10 CFR 50.73(a)(2)(i)(B) and 10 CFR 50.73(a)(2)(v).

Results of testing performed by Delphi Control Systems, the Hydrogen-Oxygen analyzer vendor, confirmed that the Hydrogen-Oxygen analyzer pump will function with the discharge piping filled with water and rising greater than 45 feet above the pump. Successful completion of the testing demonstrates that Division I Hydrogen-Oxygen analyzer did not need to be considered inoperable and therefore, there was no reportable event.

Very truly yours,



Michael F. Peckham
Plant Manager - NMP2

MFP/CES

xc: Mr. H. J. Miller, NRC Regional Administrator, Region I
Mr. G. K. Hunegs, NRC Senior Resident Inspector
Records Management

JE22