



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER AND LIGHT COMPANY
PENNSYLVANIA ELECTRIC COMPANY

DOCKET NO. 50-289

(Three Mile Island Nuclear Station, Unit 1)

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 3
License No. DPR-50

1. The Atomic Energy Commission (the Commission) having found that:
 - A. A temporary condition which was included in the operating license is no longer applicable or necessary; amendment to delete that condition is therefore warranted;
 - B. The facility will operate in conformity with the license, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. Prior public notice of this amendment is not required since the amendment does not involve a significant hazards consideration.
2. Accordingly, Paragraph 2.C.(1) of Facility License No. DPR-50 is hereby amended to read as follows:

"(1) Maximum Power Level

Metropolitan Edison Company is authorized to operate the facility at steady state reactor core power levels not in excess of 2535 megawatts thermal."

3. This license amendment is effective as of the date of its issuance.

FOR THE ATOMIC ENERGY COMMISSION

Original Signed by

Voss A. Moore, Assistant Director
for Light Water Reactors, Group 2
Directorate of Licensing

Date of Issuance: JUN 24 1974