

UNITED STATES ATOMIC ENERGY COMMISSION

DOCKET NO. 50-289

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER AND LIGHT COMPANY
PENNSYLVANIA ELECTRIC COMPANY

NOTICE OF ISSUANCE OF FACILITY LICENSE AMENDMENT

Notice is hereby given that the U. S. Atomic Energy Commission (the Commission) has issued Amendment No. 4 to Facility Operating License No. DPR-50 issued to Metropolitan Edison Company, Jersey Central Power and Light Company and Pennsylvania Electric Company, for operation of Three Mile Island Nuclear Station, Unit 1, located in Dauphin County, Pennsylvania. The amendment is effective as of July 12, 1974.

The amendment sets operating power limits for the plant when steam safety valves are not operable. This amendment relates to radiological safety matters previously considered but does not involve a significant hazards consideration.

For further details with respect to this action, see (1) the licensees' letter dated July 17, 1974, and (2) the Commission's related Safety Evaluation, dated July 12, 1974. These are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Government Publication Section, State Library of Pennsylvania, Box 1601 (Education Building), Harrisburg, Pennsylvania. A copy of item (2) may be obtained upon request addressed to the United States Atomic Energy Commission, Washington, D. C. 20545, Attention: Deputy Director for Reactor Projects, Directorate of Licensing - Regulation.

Dated at Bethesda, Maryland, this AUG 16 1974

FOR THE ATOMIC ENERGY COMMISSION

Original Signed by

Albert Schwencer

A. Schwencer, Branch Chief
Light Water Reactors Branch 2-3
Directorate of Licensing