

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-289

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER AND LIGHT COMPANY
PENNSYLVANIA ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 30 to Facility Operating License No. DPR-50, issued to Metropolitan Edison Company, Jersey Central Power and Light Company, and Pennsylvania Electric Company (the licensees), which revised Technical Specifications for operation of the Three Mile Island Nuclear Station, Unit No. 1 located in Dauphin County, Pennsylvania. The amendment is effective as of its date of issuance.

This amendment adds provisions to the Technical Specifications to require operability and surveillance of shock suppressors (snubbers) required to protect the primary coolant system and all other safety related systems and components.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.


The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated August 23, 1975, as supplemented September 15 and October 19, 1976, and March 9, 1977, (2) the Commission's letter dated February 17, 1977 to Metropolitan Edison Company, (3) Amendment No.30 to License No. DPR-50, and (4) the Commission's related Safety Evaluation issued February 17, 1977. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Government Publications Section, State Library of Pennsylvania, Box 1601 (Education Building), Harrisburg, Pennsylvania.

A copy of items (2), (3), and (4) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 11th day of May 1977.

FOR THE NUCLEAR REGULATORY COMMISSION


Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors