

December 11, 2000

Mr. James A. Hutton  
Director-Licensing  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control  
P.O. Box 160  
Kennett Square, PA 19348

SUBJECT: UPDATED TECHNICAL SPECIFICATIONS (TS) BASES PAGES - LIMERICK  
GENERATING STATION (LGS), UNITS 1 AND 2 (TAC NOS. MB0342 AND  
MB0343)

Dear Mr. Hutton:

By letter dated May 5, 2000, PECO Energy Company submitted a change to TS Bases Section 3/4.5.1 and 3/4.5.2 (combined), "ECCS-Operating and Shutdown," to support LGS Units 1 and 2, condensate storage tank (CST) online cleaning activities. TS Bases pages B 3/4 5-1 for LGS Units 1 and 2 were revised to clarify that the high pressure coolant injection (HPCI) system is normally aligned to the CST for injection of water into the reactor vessel. The HPCI system can also be aligned to the suppression pool as a source of water. Since the Bases are not part of the TSs, the NRC staff is not approving the Bases change, but is forwarding the revised Bases pages for completeness (pages B 3/4 5-1 for LGS Units 1 and 2).

Sincerely,

*/RA/*

Bartholomew C. Buckley, Sr Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

Enclosure: As stated

cc w/encl: See Next Page

Limerick Generating Station, Units 1 & 2

cc:

J. W. Durham, Sr., Esquire  
Sr. V.P. & General Counsel  
PECO Energy Company  
2301 Market Street  
Philadelphia, PA 19101

Manager-Limerick Licensing  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control  
P.O. Box 160  
Kennett Square, PA 19348

Mr. James D. von Suskil, Vice President  
Limerick Generating Station  
Post Office Box 2300  
Sanatoga, PA 19464

Plant Manager  
Limerick Generating Station  
P.O. Box 2300  
Sanatoga, PA 19464

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Limerick Generating Station  
P.O. Box 596  
Pottstown, PA 19464

Chairman  
Board of Supervisors  
of Limerick Township  
646 West Ridge Pike  
Linfield, PA 19468

Chief-Division of Nuclear Safety  
PA Dept. of Environmental Resources  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Director-Site Engineering  
Limerick Generating Station  
P.O. Box 2300  
Sanatoga, PA 19464

Manager-Experience Assessment  
Limerick Generating Station  
P.O. Box 2300  
Sanatoga, PA 19464

Library  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Senior Manager-Operations  
Limerick Generating Station  
P.O. Box 2300  
Sanatoga, PA 19464

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Mr. James A. Hutton  
Director-Licensing  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control  
P. O. Box 160  
Kennett Square, PA 19348

December 11, 2000

Mr. James A. Hutton  
Director-Licensing  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control  
P.O. Box 160  
Kennett Square, PA 19348

SUBJECT: UPDATED TECHNICAL SPECIFICATIONS (TS) BASES PAGES - LIMERICK  
GENERATING STATION (LGS), UNITS 1 AND 2 (TAC NOS. MB0342 AND  
MB0343)

Dear Mr. Hutton:

By letter dated May 5, 2000, PECO Energy Company submitted a change to TS Bases Section 3/4.5.1 and 3/4.5.2 (combined), "ECCS-Operating and Shutdown," to support LGS Units 1 and 2, condensate storage tank (CST) online cleaning activities. TS Bases pages B 3/4 5-1 for LGS Units 1 and 2 were revised to clarify that the high pressure coolant injection (HPCI) system is normally aligned to the CST for injection of water into the reactor vessel. The HPCI system can also be aligned to the suppression pool as a source of water. Since the Bases are not part of the TSs, the NRC staff is not approving the Bases change, but is including the revised Bases pages for completeness (pages B 3/4 5-1 for LGS Units 1 and 2).

Sincerely,

**/RA/**

Bartholomew C. Buckley, Senior Project Manager, Section 2  
Project Directorate I  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

Enclosure: As stated

cc w/encl: See Next Page

Distribution:

PD1-2	EAdensam	BPlatchek, RI
Public	WBeckner	JWermiel
JClifford	OGC	GHill(4)
BBuckley	ACRS	MOBrien

Accession No.: ML003763113

\*See previous concurrence

OFC	PDI-2/PM	PDI-2/LA	PD1-2/SC	RTSB	SRXB*
NAME	BBuckley	MOBrien	VNerses for JClifford	<del>WBeckner</del>	JWermiel
DATE	12/5/00	11/28/00	12/5/00		11/22/00

OFFICIAL RECORD COPY