UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-289

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 19 to Facility Operating License No. DPR-50, issued to Metropolitan Edison Company, Jersey Central Power and Light Company, and Pennsylvania Electric Company which revised Technical Specifications for operation of the Three Mile Island Nuclear Station, Unit No. 1, located in Dauphin County, Pennsylvania. The amendment is effective as of its date of issuance.

The amendment revises the Technical Specifications to require positive blocking of electrical power to the Core Flood Tank vent valves except under specified conditions and to require periodic venting of the pumps and lines associated with the Low Pressure Injection and High Pressure Injection Systems.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-289

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 19 to Facility Operating License No. DPR-50, issued to Metropolitan Edison Company, Jersey Central Power and Light Company, and Pennsylvania Electric Company which revised Technical Specifications for operation of the Three Mile Island Nuclear Station, Unit No. 1, located in Dauphin County, Pennsylvania. The amendment is effective as of its date of issuance.

The amendment revises the Technical Specifications to require positive blocking of electrical power to the Core Flood Tank vent valves except under specified conditions and to require periodic venting of the pumps and lines associated with the Low Pressure Injection and High Pressure Injection Systems.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR \$51.5(d)(4) an environmental impact statement, negative declaration or environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated July 12, 1976, (2) Amendment No. 19 to License No. DPR-50, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Government Publications Section, State Library of Pennsylvania, Box 1601 (Education Building), Harrisburg, Pennsylvania.

A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 23rd day of August 1976.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert W. Reid, Chief

Operating Reactors Branch #4

Division of Operating Reactors