


ADDENDUM TO
SAFETY EVALUATION BY THE
DIRECTORATE OF LICENSING
SUPPORTING AMENDMENT NO. 4
TO LICENSE NO. DPR-50
(Change No. 3 to Appendix A
of Technical Specifications)


The staff safety evaluation, dated July 12, 1974, discusses the justification of the change to Technical Specification 3.4.1 to permit plant operation with disabled steam safety valves provided that the overpower trip setting is reduced. While incorporating this change into the Technical Specifications, a number of purely editorial changes are appropriate for this page (3-25) of the Technical Specifications. They are:

- a. Specification 3.4.7 - delete since this applied only until the plant achieved 5% power for the first time. The specification is now obsolete.
- b. Specifications 3.4.2 to 3.4.6 - renumber these to 3.4.1 to 3.4.5 to simplify wording and clarify intent that the 48-hour maintenance allowance (old 3.4.6) applies to all equipment except steam safety valves.
- c. Specification 3.4.1 - renumber as 3.4.6 and revise to state required reduction in overpower trip set points, etc.

These changes to page 3-25 are purely editorial and do not affect the conclusions of the staff safety evaluation, dated July 12, 1974.



Robert M. Bernero, Project Manager
Light Water Reactors Branch 2-3
Directorate of Licensing



J. A. Pettier
A. Schwencer, Chief
Light Water Reactors Branch 2-3
Directorate of Licensing

Date of Issuance: JUL 19 1974