



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

DOCKET NO. 50-289

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 59
License No. DPR-50

- I. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Metropolitan Edison Company, Jersey Central Power and Light Company and Pennsylvania Electric Company (the licensees), dated August 30, 1978 and revised by letters dated March 31 and June 9, 1980 and staff discussions, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-50 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 59, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 31, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 59

FACILITY OPERATING LICENSE NO. DPR-50

DOCKET NO. 50-289

Revise Appendix A as follows:

<u>Remove Pages</u>	<u>Insert Pages</u>
ii	ii
v	v
vii	vii
4-35 through 4-36f	3-95
Figures 4.4-1 through 4.4-5	4-35
Tables 4.4-1 through 4.4-3	4-35a
6-18	4-36
	6-18

The changes on the revised pages are shown by marginal lines.

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
3.1.3	MINIMUM CONDITIONS FOR CRITICALITY	3-6
3.1.4	REACTOR COOLANT SYSTEM ACTIVITY	3-8
3.1.5	CHEMISTRY	3-10
3.1.6	LEAKAGE	3-12
3.1.7	MODERATOR TEMPERATURE COEFFICIENT OF REACTIVITY	3-16
3.1.8	SINGLE LOOP RESTRICTIONS	3-17
3.1.9	LOW POWER PHYSICS TESTING RESTRICTIONS	3-18
3.1.10	CONTROL ROD OPERATION	3-18a
3.1.11	REACTOR INTERNALS VENT VALVES	3-18b
3.2	<u>MAKEUP AND PURIFICATION AND CHEMICAL ADDITION SYSTEMS</u>	3-19
3.3	<u>EMERGENCY CORE COOLING, REACTOR BUILDING EMERGENCY COOLING, AND REACTOR BUILDING SPRAY SYSTEMS</u>	3-21
3.4	<u>TURBINE CYCLE</u>	3-25
3.5	<u>INSTRUMENTATION SYSTEMS</u>	3-27
3.5.1	OPERATIONAL SAFETY INSTRUMENTATION	3-27
3.5.2	CONTROL ROD GROUP AND POWER DISTRIBUTION LIMITS	3-33
3.5.3	ENGINEERED SAFEGUARDS PROTECTION SYSTEM ACTUATION SETPOINTS	3-37
3.5.4	INCORE INSTRUMENTATION	3-38
3.6	<u>REACTOR BUILDING</u>	3-41
3.7	<u>UNIT ELECTRICAL POWER SYSTEM</u>	3-42
3.8	<u>FUEL LOADING AND REFUELING</u>	3-44
3.9	<u>RADIOACTIVE MATERIALS</u>	3-46
3.10	<u>MISCELLANEOUS RADIOACTIVE MATERIALS SOURCES</u>	3-46
3.11	<u>HANDLING OF IRRADIATED FUEL</u>	3-55
3.12	<u>REACTOR BUILDING POLAR CRANE</u>	3-57
3.13	<u>SECONDARY SYSTEM ACTIVITY</u>	3-58
3.14	<u>FLOOD</u>	3-59
3.14.1	PERIODIC INSPECTION OF THE DIKES AROUND TMI	3-59
3.14.2	FLOOD CONDITION FOR PLACING THE UNIT IN HOT STANDBY	3-60
3.15	<u>SHOCK SUPPRESSORS (SNUBBERS)</u>	3-63
3.16	(RESERVED)	
3.17	<u>REACTOR BUILDING AIR TEMPERATURE</u>	3-80
3.18	<u>FIRE PROTECTION</u>	3-86
3.19	<u>CONTAINMENT SYSTEMS</u>	3-95
4	<u>SURVEILLANCE STANDARDS</u>	4-1
4.1	<u>OPERATIONAL SAFETY REVIEW</u>	4-1
4.2	<u>REACTOR COOLANT SYSTEM INSERVICE INSPECTION</u>	4-11
4.3	<u>TESTING FOLLOWING OPENING OF SYSTEM</u>	4-28
4.4	<u>REACTOR BUILDING</u>	4-29
4.4.1	CONTAINMENT LEAKAGE TESTS	4-29
4.4.2	STRUCTURAL INTEGRITY	4-35
4.4.3	HYDROGEN PURGE SYSTEM	4-37
4.5	<u>EMERGENCY LOADING SEQUENCE AND POWER TRANSFER, EMERGENCY CORE COOLING SYSTEM AND REACTOR BUILDING COOLING SYSTEM PERIODIC TESTING</u>	4-39
4.5.1	EMERGENCY LOADING SEQUENCE	4-39
4.5.2	EMERGENCY CORE COOLING SYSTEM	4-41
4.5.3	REACTOR BUILDING COOLING AND ISOLATION SYSTEM	4-43
4.5.4	DECAY HEAT REMOVAL SYSTEM LEAKAGE	4-45

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
2.3-1	Reactor Protection System Trip Setting Limits	2-9
3.5-1	Instruments Operating Conditions	3-29
3.16-1	Safety Related Shock Suppressors (Snubbers)	3-65
3.18-1	Fire Detection Instruments	3-87
4.1-1	Instrument Surveillance Requirements	4-3
4.1-2	Minimum Equipment Test Frequency	4-8
4.1-3	Minimum Sampling Frequency	4-9
4.2-1	Instrument Surveillance Program	4-14
4.2-2	Surveillance Capsule Insertion & Withdrawal Schedule at TMI-2	4-27a
4.4-1	Deleted	
4.4-2	Deleted	
4.4-3	Deleted	
4.15-1	Radioactive Liquid Waste Sampling and Analysis	4-59
4.15-2	Radioactive Gaseous Waste Sampling and Analysis	4-63
4.19-1	Minimum Number of Steam Generators to be Inspected During Inservice Inspection	4-84
4.19-2	Steam Generator Tube Inspection	4-85
6.12-1	Deleted	

FIGURES

TITLE

3.5-2F	Deleted
3.5-2G	LOCA Limited Maximum Allowable Linear Heat Rate - TMI-1
3.5-2H	APSR Position Limits for Operation from 0 EFPD to EOC
3.5-2I	Deleted
3.5-2J	Deleted
3.5-2K	Deleted
3.5-2L	Deleted
3.5-2M	Deleted
3.5-2N	Deleted
3.5-3	Incore Instrumentation Specification, TMI-1
4.2-1	Equipment and Piping Requiring Inservice Inspection in Accordance with Section XI of the ASME Code
4.4-1	Deleted
4.4-2	Deleted
4.4-3	Deleted
4.4-4	Deleted
4.4-5	Deleted
6-1	Met-Ed Corporate Technical Support Staff and Station Organization Chart

3.19 CONTAINMENT SYSTEMS

3.19.1 CONTAINMENT STRUCTURAL INTEGRITY

APPLICABILITY: Applies to the structural integrity of the reactor building.

OBJECTIVE: To define the inservice tendon surveillance program for the reactor building prestressing system.

Specification

- 3.19.1.1 With the structural integrity of the containment not conforming to the requirements of 4.4.2.1.1.b, perform an engineering evaluation of the structural integrity of the containment to determine if COLD SHUTDOWN is required. The margins available in the containment design may be considered during the investigation. If the acceptability of the containment tendons cannot be established within 48 hours, restore the structural integrity to within the limits within 24 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- 3.19.1.2 With the structural integrity of the containment otherwise not conforming to the requirements of Specification 4.4.2.1, submit a report to the Commission pursuant to NRC Regulatory Guide 1.16, Rev. 3. This report shall include a description of the tendon condition, the condition of the concrete (especially at tendon anchorages), the inspection procedures, the tolerances on cracking, and the corrective actions taken. The report of each completed tendon surveillance will include a section dealing with trends for the rate of prestress loss as compared to the predicted rate for the duration of the plant life (after an adequate number of surveillances have been completed). This report will be submitted to the NRC per Specification 6.9.3.a(1).

4.4.2 Structural Integrity

Specification

4.4.2.1 Inservice Tendon Surveillance Requirements

The surveillance program for structural integrity and corrosion protection conforms to the recommendations of the U.S. Atomic Energy Commission Regulatory Guide 1.35, proposed Revision 3, "Inservice Surveillance of Ungrouted Tendons in Prestressed Concrete Containment Structures." The detailed surveillance program for the prestressing system tendons shall be based on periodic inspection and mechanical tests to be performed on selected tendons, as specified hereafter.

4.4.2.1.1 Containment Tendons

Tendon surveillance was completed for one year and three years following the initial structural integrity using a Tech Spec. based on Regulatory Guide 1.35 Rev. 1. The containment tendons structural integrity shall be demonstrated at the end of five years following the initial containment structural integrity test and at five year intervals thereafter by:

- a. Determining that for a representative sample* of at least 23 tendons (6 dome, 7 vertical, and 10 hoop) each tendon has a lift off force equalling, or exceeding, its lower limit predicted for the time of the test as defined in NRC Regulatory Guide 1.35, "Inservice Inspection for Ungrouted Tendons in Prestressed Concrete Containments", Proposed Revision 3, April, 1979.

If the lift off force of a selected tendon in a group lies between the prescribed lower limit and 90% of that limit, one tendon on each side of this tendon shall be checked for their lift off forces. If the lift off forces of the adjacent tendons are equal to, or greater than, their prescribed lower limits at the time of the test, the single deficiency shall be considered unique and acceptable. If the lift off force of either of the adjacent tendons lies below the prescribed lower limit for that tendon, the condition is reportable per T.S. 6.9.2.A3.

If the lift off force of any one tendon lies below 90% of its prescribed lower limit, the tendon shall be considered a defective tendon. It shall be completely detensioned and a determination made as to the cause of the occurrence. The condition is reportable per T.S. 6.9.2.A3.

If the inspections performed at one, three, and five years indicate no abnormal degradation of the post-tensioning system, the number of tendons checked for lift off force during subsequent tests may be reduced to a representative sample of at least 11 tendons (3 dome, 3 vertical, and 5 hoop).

* For each inspection, the tendons shall be selected on a random but representative basis so that the sample group will change somewhat for each inspection; however, to develop a history of tendon performance and to correlate the observed data, one tendon from each group (dome, vertical, and hoop) may be kept unchanged after the initial selection.

- b. Determining that the average of the normalized* tendon lift off forces for each tendon group (vertical, dome, and hoop) is equal to, or greater than 1010 Kips for vertical tendons, 1040 Kips for dome tendons, and 1121 Kips for hoop tendons. If this requirement is not met, the condition is reportable per T.S. 6.9.2.A3 and an additional sample of 4%, with a minimum of four and a maximum of ten, of the same group of tendons shall be inspected. If the total population of each group of the sampled tendons meets the criteria above, the structural integrity of the containment shall be considered acceptable.
- c. Detensioning one tendon in each group (dome, vertical and hoop) from the representative sample. One wire shall be removed from each detensioned tendon and examined to determine:
1. That over the entire length of the wire, the tendon wires have not undergone corrosion, cracks, or damage beyond that which was originally recorded and the extent of corrosion is within specified acceptable limits. Failure to satisfy these limits is a reportable condition per T.S. 6.9.2.A3.
 2. A minimum tensile strength value of 240,000 psi (guaranteed ultimate strength of the tendon material) for at least three wire samples (one from each end and one at mid-length) cut from each removed wire. Failure of any one of the wire samples to meet the minimum tensile strength test is reportable per T.S. 6.9.2.A3.

Upon retensioning, the elongation shall be within plus or minus 5% of that recorded at original stressing of the tendon. If the 5% limit is not met, an investigation shall be made to determine if wire failure is the cause.

- d. Determining for each tendon in the above representative sample, that the sheathing filler grease is within acceptable limits as to:
1. presence of voids.
 2. presence of free water.
 3. chemical and physical properties.

Failure of the grease to meet acceptable limits is reportable per T.S. 6.9.2.A9.

* In order for the tendon lift off forces to be indicative of the average level of prestress, each lift off force is adjusted for differences which exist among the tendons due to initial lock off force and elastic shortening loss.

4.4.2.1.2 End Anchorages and Adjacent Concrete Surfaces

The structural integrity of the end anchorages of all tendons inspected pursuant to Specification 4.4.2.1.1 and the adjacent concrete surfaces shall be determined through visual inspection. The condition of the end anchorage and adjacent concrete shall be recorded. The acceptance criteria shall be that all crack widths greater than 0.010 inch shall be recorded and evaluated. Any crack width greater than 0.050 inch shall be cause for investigation to determine the amount of structural impairment upon the reactor building and its continued structural integrity. Changes in the condition of the end anchorage or the concrete from that previously recorded shall be noted on the record. Any condition or change in condition which indicates abnormal material or structural behavior is reportable.

4.4.2.1.3 Containment Surfaces

The structural integrity of the exposed accessible interior and exterior surfaces of the containment, including the liner plate, shall be determined during the shutdown for each Type A containment leakage rate test (specification 4.4.1.1) by a visual inspection of these surfaces. This inspection shall be performed prior to the Type A containment leakage rate test. Any abnormal degradation must be documented and if it affects structural integrity it is reportable per T.S. 6.9.2.A9.

4.4.2.1.4 Tendon Surveillance Previous Inspections

The tendon surveillance shall include the reexamination of all abnormalities (i.e., concrete scaling, cracking, grease leakage, etc.) discovered in the previous inspection to determine whether conditions have stabilized. The inspection program shall be modified accordingly if obvious deteriorating conditions are observed.

4.4.2.1.5 Inspection for Crack Growth at Dome Tendons in the Ring Girder Anchorage Areas

Concrete around the dome tendon anchorage areas shall be inspected for crack growth during ten and 15 year inspections by monitoring cracks greater than 0.005 inch in width. Select as a minimum nine dome tendon anchoring areas having concrete cracks with crack widths 0.005 inch. In the selection of dome tendon anchoring areas to be monitored, preference shall be given to those areas having cracks greater than 0.005 inch in width. The width, depth (if depths can be measured with simple existing plant instruments, (i.e., feeler gauges, wires) and length of the selected cracks shall be measured and mapped by charting. This inspection may be discontinued, if the concrete cracks show no sign of growth. If, however, these inspections indicate crack growth, an investigation of the causes and safety impact should be performed.

6.9 REPORTING REQUIREMENTS (cont'd)

6.9.3 Unique Reporting Requirements

- A. Special reports shall be submitted to the Director of the Office of Inspection and Enforcement Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below:

<u>Tests</u>	<u>Submittal Dates</u>
(1) Containment Structural Integrity Test	
(a) Tendon Surveillance Program	Within 3 months after performance of surveillance program.
(2) Steam Generator Tube Inspection Program (See Section 4.19.5)	Within 3 months after completion of inspection.
(3) Containment Integrated Leak Rate Test	Within 6 months after completion of test.
(4) Inservice Inspection Program	Within 6 months after five years of operation.

FOOTNOTES

1. A single submittal may be made for a multiple unit station. The submittal should combine those sections that are common to all units at the station.
2. This tabulation supplements the requirements of §20.407 of 10 CFR Part 20.
3. These reporting requirements apply only to Appendix A technical specifications.