DISTRIBUTION:
Docket File
NRC PDR
L PDR

Docket No. 50-289

TERA NSIC ORB#4 Rdg DEisenhut RJacobs HSilver

RJacobs HSilver EHylton DDilanni

Mr. Henry D. Hukill, Vice President and Director - TMI-1 Metropolitan Edison Company P. O. Box 480 Middletown, Pennsylvania 17057 AEOD IE-4 ACRS-10 Gray File +4 BScharf-10 TBarnhart-4 RDiggs CMiles ASLAB JWetmore

HOrnstein EBlackwood

OELD



Dear Mr. Hukill:

The Commission has issued the enclosed Amendment No. 73 to Facility Operating License No. DPR-50 for Three Mile Island Nuclear Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in a partial response to your application dated May 18, 1981.

This amendment revises the Technical Specifications to reflect the revised system setpoint of 1600 psig to initiate high and low pressure injection from the Emergency Core Cooling System (ECCS). This revised setpoint is in accordance with the generic B&W ECCS analysis.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

John F. Stolz, Chief Operating Reactors Branch #4 Division of Licensing

Enclosures:

- 1. Amendment No. 78 to DPR-50
- 2. Safety Evaluation
- 3. Notice of Issuance

cc w/enclosures:
See next page

DISTRIBUTION:
Docket File
NRC PDR
L PDR
TERA

NSIC ORB#4 Rdg DEisenhut JStolz/RJacobs EHylton HSilver EBlackwood OELD AEOD IE-4 ACRS-10 Gray File

Docket No. 50-289 DDiIanni HOrnstein

BScharf-10 TBarnhart-4

Mr. Henry D. Hukill, Vice President and Director - TMI-1 Metropolitan Edison Company P. O. Box 480 Middletown, Pennsylvania 17057 RDiggs CMiles ASLAB JWetmore

Dear Mr. Hukill:

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-50 for Three Mile Island Nuclear Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in a partial response to your application dated May 18, 1981.

This amendment revises the Technical Specifications to reflect the revised Engineered Safety Features Actuation System setpoint of 1600 psig. This revised setpoint is in accordance with the generic B&W Emergency Core Cooling System (ECCS) analysis.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

John F. Stolz, Chief Operating Reactors Branch #4 Division of Licensing

Enclosures:

1. Amendment No. to DPR-50

2. Safety Evaluation

3. Notice of Issuance

cc w/enclosures: See next page

OFFICE	ORB#4:DL	ORB#4:DL	C-ORB#4:DL	AD-OR:DL	OELD	 
	EH97900	RJacobs/cb	JStolz	TNovak		
DATE &	8 <i>J</i> 25781	8/ /81	8/ /8 1	8/ /81	8/ /81	
5//L						