

ENCLOSURE 2

CON EDISON PRESENTATION MATERIAL FROM SEPTEMBER 26, 2000 REGULATORY CONFERENCE

Consolidated Edison Company Of New York

Indian Point 2

NRC Regulatory Conference

September 26, 2000

OVERVIEW

- **Phase 3 Risk Assessment Analysis**
- **Risk Associated With 2/15 Event**
- **Risk With Cycle 14 Operation**

2

OVERVIEW

- **SG Inspection - 1997**
- **Measures To Prevent Recurrence**

3

Site Specific Conclusions

- **Failed Tube Did Not "Rupture"**
 - Actual Leak Rate < 150 gpm
 - Charging Pumps Capacity ~ 225 gpm
- **Delta CDF - White**
- **Delta LERF - Yellow**

4

In-Situ Testing - 2000

- **Tested - 51 Tubes, 48 With Indications**
 - Tested All Axial Indications (23)
- **All Tubes Met 3 Delta-P Burst Margin Criteria**
- **Negligible Leakage At SLB Test Conditions**

5

ANALYSIS OF PROBABILITY OF RUPTURE

Tom Esselman

6

Objectives

- **Identify PWSCC Mechanisms**
- **IP-2 Crack Growth Is Understood**
- **Define Likelihood Of Tube Rupture**

7

IP2 Row 2 U-Bends With Hour-Glassing

- **Stress Distribution**
- **Mechanism Of PWSCC Crack Initiation And Growth**
- **Behavior Of The IP-2 Row 2 U-Bends**


8

PWSCC Initiation & Growth Process


- **Cracks Initiate At Multiple Sites**
- **Small Cracks Grow And Eventually Link To Form Larger Cracks**
- **High Aspect Ratio Cracks (Ratio Of Length To Depth) Grow Until Stress in the Remaining Ligament Exceeds Material Failure Stress**

9

Crack Linkup & Growth




Lab Crack



IP2 SG 24
R2C69

10

R2C5 CRACK



Mill Annealed Alloy 600 Properties

- Susceptible To PWSCC
- However!!!

Material is Extremely Ductile



Very High Toughness




Crack Blunting



Crack Propagation
By Overload
vs.
Unstable Crack Growth


12

Mill Annealed Alloy 600 Test



13

Crack Blunting Behavior



All Loads Above Net Section Yield (49.5 KSI)

14



R2C5



Lab



15


Crack Locations

Extrados Crack Summary by SG Tube




16

Location And Size Of Cracks Correlate Well With Stress Distribution




17

Location And Size Of Cracks Correlate Well With Stress Distribution




Location And Size Of Cracks Correlate Well With Stress Distribution



Location And Size Of Cracks Correlate Well With Stress Distribution

Extrados Hoop Stresses to the Fourth Power Normalized to the Apex Stress to the Fourth Power
Hourglassing = 0.476" for Average Yield Strength, Row 2 Tubes



20

Crack Stability

- Cracks Initiate, Grow, And Link
- Linked Cracks Grow Thru-Wall And Then Extend Axially By Linking With Adjacent Cracks
- High Toughness Inhibits Crack Propagation Into Areas With No Cracks Or Shallow Cracks


21

Correlating Flow Rate With Crack Length

- Equivalent U-Bend Cracks Result In A Smaller Flow Rate, Due To Geometry Restraint And Work Hardened Material.
- Supported By Industry Experience

22

Leak Rate vs. Crack Length For Cracks In Straight Tubes And U-Bends



Ref: NUREG 6365

23

Probability Of Failure Objectives

- **Determine Progressive “Events” Associated With Tube Failure**
- **Determine Probability Associated With Each Based On IP-2 Conditions**
- **Use Monte Carlo Analysis Methods To Determine Probability Of Failure**

24

Events

- **Number Of Tubes With Undetected Cracks**
- **Depth Of Cracks**
- **Crack Growth Rate**
- **Crack Penetrating Wall**
- **Axial Length Of Crack**
- **Flow Rate Through Crack**

25

Postulated Number Of Tubes With Undetected Cracks

- **100 Row 2 U-Bends Assumed To Have Cracks**
 - **7 U-Bends Had Axial Indications Identified In 2000 Inspection**
 - **Conservatively Assumed 100 Tubes Left In Service For Monte Carlo Analysis**

26

Postulated Depth of Cracks

- **Assumed A Depth Of Cracks From 0% to 90% Thru-Wall**
- **Population For Over 50% Thru-Wall Indications Exceeded The Number Found In The 2000 Inspection**

27

Postulated Crack Growth Rate

- **Assumed Growth Rates Of 4% To 20% Thru-wall Per EFPY**
- **2000 Inspection Showed Growth Rates Of 0% To 16% Thru-wall Per EFPY**
- **Typical Growth Below 8% Per EFPY**

28

Postulated Crack Penetration Of Wall

- **Assumed 100% Probability Of Leakage At 80% Thru-wall**
- **Assumed 10% Probability Of Leakage At 70% To 80% Thru-wall**

29

Postulated Axial Length Of Crack

- Axial Length Of Cracks Assumed To Range From 0" To 4.5" Long
- Highest Probability Is For Cracks In 2" To 2.5" Range
- 37% Of The Cracks Assumed To Be Longer Than 2.5"
- Assumptions Are Conservative Compared To 2000 Inspection Results

30

Estimate Of Flow Rates

- Crack Length Converted To Flow Rate Based On NUREG 6365 Data
- If Leakage Occurred, Was It Above Or Below 225 gpm?

31

Factors for Monte Carlo Analysis

	IP-2	Monte Carlo Analysis
Number of U-Bends With Cracks In 97 Inspection	7	100
Depth of Cracks (# of Tubes Exceeding 50% Thru-wall)	4 Tubes	19 Tubes
Crack Growth Rate (% of Tubes exceeding 8% Thru-wall Per Year)	40%	42%
Axial Length of Flaw (# of Tubes Exceeding 2.5")	0 Tubes	37 Tubes

32

Monte Carlo Analysis

- 10,000 Trials Performed
- Results Indicated The Following Probabilities:
 - Spontaneous Failure
 - > 225 gpm - .038 Per Year
 - > 75 gpm, < 225 gpm - .275 Per Year
 - Steam Line Break
 - > 225 gpm - .040 Per Demand
 - > 75 gpm, < 225 gpm - .275 Per Demand

33

Site Specific Risk Assessment

Douglas Gaynor
Con Edison

34

Site Specific Risk Assessment

**Preliminary "RED" Safety Significance Based On Delta
CDF And LERF From 4 Postulated Scenarios:**

- **Spontaneous SGTR**
- **SGTR Induced By Secondary Depressurization**
- **SGTR Induced By Over Pressurization**
- **SGTR Induced By Temperature And Pressure After
Core Damage**

35

Site Specific Risk Assessment

SGTR Induced By Over Pressurization

- No Delta CDF From ATWS
- IP2 RPS Model Modified Since IPE
- ATWS CDF For Current Model $< 5 \times 10^{-7}$

36

Site Specific Risk Assessment

Temperature Induced SGTR

- IP-2 IPE Used NUREG 1150:
1.8% Of "High/dry" Sequences Induce SGTR
- Technical Basis Reviewed:
 - IP-2 In-situ Testing
 - 1/7th Scale SG Experiments
 - TMI - 2 Experience
 - Industry Analysis
 - NRC Analysis
- No Change In CDF Or LERF

37

Site Specific Risk Assessment

Spontaneous SGTR (>225 gpm)

- "Rupture" Frequency of $3.85 \times 10^{-2}/\text{RY}$
- Evaluated Using IP-2 Full SGTR Model

38

Site Specific Risk Assessment

Spontaneous SGTR (> 225 gpm)

- Conditional Probability of LERF = 0.13
- Separate Plant Damage States
- Many Sequences Involve Late Releases

39

Site Specific Risk Assessment

Spontaneous SGTR (<225 gpm)

- Frequency = $2.75 \times 10^{-1}/\text{RY}$
- Evaluated Using IP-2 SGTR Model
(adjusted for 225 gpm)

40

Site Specific Risk Assessment

Spontaneous SGTR

- Results For Two Cases Combined
- Change In CDF = $3.8 \times 10^{-6} / \text{RY}$
- Change In LERF = $1.1 \times 10^{-6} / \text{RY}$

41

Site Specific Risk Assessment

SGTR Induced by Secondary Side Depressurization (SSD)

- **Used NRC IE Frequency**
- **Conditional SG Tube Failure Probabilities**
 - 0.28 for > 75 gpm
 - 0.039 for > 225 gpm

42

Site Specific Risk Assessment

SGTR Induced by Secondary Side Depressurization (SSD)

- **Evaluated Using Modified IP-2 SGTR
Model**
- **EOP Guidance and Operator Training**

43

Site Specific Risk Assessment

- **IP-2 Emergency Operating Procedures
Provide Clear Guidance**
 - **ECA 3.1 SGTR With Loss of Reactor Coolant -
Subcooled Recovery Desired**

44

Site Specific Risk Assessment

- **Operator Training on Simulator**
(per crew, lesson every 2 years minimum)
 - Once in 1996
 - Once in 1998
 - Twice in 1999
 - Once in 2000

45

Site Specific Risk Assessment

SGTR Induced by Secondary Side Depressurization (SSD)

- Evaluated Using Modified IP-2 Risk Assessment Model
- Change in CDF = $2.9 \times 10^{-6}/\text{RY}$
- Change in LERF = $2.9 \times 10^{-6}/\text{RY}$

46

Site Specific Risk Assessment

No.	Postulated Scenario	Con Ed Calculated Δ CDF	Con Ed Calculated Δ LERF
1	ATWS Induced Tube Rupture	0.0	$<5 \times 10^{-7}$
2	High Temp Induced Tube Rupture	0.0	0.0
3	Spontaneous Tube Rupture	3.8×10^{-6}	1.1×10^{-6}
4	Steam Line Break Induced Tube Rupture	2.9×10^{-6}	2.9×10^{-6}
Total		6.7×10^{-6}	$< 4.5 \times 10^{-6}$
Color For Total		WHITE	YELLOW

47

1997 Inspection Measures to Prevent Recurrence

J. O. Parry

48

1997 Inspection

- **Meeting July 20th, 2000 with NRC**
- **1997 Inspection Performed per Industry Guidelines**
 - Scope
 - Probes
 - Oversight
 - Independent Engineering Studies 95, 97

49