

SEPTEMBER 02 1980

DISTRIBUTION:

Docket File

NRC PDR  
L PDR

Docket No. 50-289

TERA  
NSIC  
ORB#4 Rdg  
NRR Rdg  
HDenton  
DEisenhut  
RPurple  
TNovak

JOlshinski  
RTedesco  
GLainas  
DDianni  
EHylton  
ACRS-16  
IE-5  
BJones-4  
BScharf-10  
JWetmore  
RDiggs  
CMiles

Gray File +4  
TMI SEP r/f  
TMI Site r/f  
TMI PS r/f  
BSnyder  
TSpeiss

Mr. R. C. Arnold  
Senior Vice President  
Metropolitan Edison Company  
100 Interpace Parkway  
Parsippany, New Jersey 07054

Dear Mr. Arnold:

The Commission has issued the enclosed Amendment No. 57 to Facility Operating License No. DPR-50 for Three Mile Island Nuclear Station, Unit No. 1 (TMI-1). The amendment consists of changes to the Technical Specifications in response to your request dated September 7, 1977 (GQL 1202), and revised by letters dated October 21, 1977 (GQL 1428), March 31 and May 20, 1980, and staff discussions.

The amendment revises the Technical Specifications for TMI-1 to include surveillance requirements for High and Low Pressure Safety Injection Systems. These surveillance requirements will provide additional assurance that these systems will function as assumed in the ECCS analysis. Changes to your proposal, necessary to meet our requirements, have been discussed with and agreed to by your staff.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Original signed by  
Robert W. Reid

Robert W. Reid, Chief  
Operating Reactors Branch #4  
Division of Licensing

Enclosures:

1. Amendment No. 57
2. Safety Evaluation
3. Notice of Issuance

cc w/enclosures: See next page

OFFICE	ORB#4:DL	ORB#4:DL W	C-ORB#4:DL	AD-OR.DL	OELD	OSB:DSI
SURNAME	EHylton	DDianni/cb	RReid	TNovak	COTCHNI	TSpeiss
DATE	8/1/80	8/2/80	8/1/80	8/5/80	8/15/80	8/9/80

*No hand delivery to Paris  
of letter or amendment*

7-29-80  
w/28  
8/9/80