



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER & LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

DOCKET NO. 50-289

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52
License No. DPR-50

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Metropolitan Edison Company, et al. (the licensee) dated October 11, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations,
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Operating License No. DPR-50 is amended by revising paragraph 2.c.(2) and adding paragraph 2.c.(5) as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 52, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

- (5) The licensee shall implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. This program shall include:

8003060 726
726

1. Identification of a sampling schedule for the critical parameters and control points for these parameters;
 2. Identification of the procedures used to measure the values of the critical parameters;
 3. Identification of process sampling points;
 4. Procedure for the recording and management of data;
 5. Procedures defining corrective actions of off control point chemistry conditions; and
 6. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.
3. This license amendment is effective within 60 days from the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Operating Reactors

Date of Issuance: February 20, 1980