

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-289METROPOLITAN EDISON COMPANYJERSEY CENTRAL POWER AND LIGHT COMPANYPENNSYLVANIA ELECTRIC COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 68 to Facility Operating License No. DPR-50, issued to Metropolitan Edison Company, Jersey Central Power and Light Company, and Pennsylvania Electric Company (the licensees), which revised Technical Specifications for operation of the Three Mile Island Nuclear Station, Unit No. 1 (the facility) located in Dauphin County, Pennsylvania. The amendment is effective as of its date of issuance.

The amendment revises the Technical Specifications for the facility to extend the surveillance period for some of the equipment and systems from February 1981 to the restart date of TMI-1 and to delete the requirement to perform the emergency core cooling system emergency loading sequence test prior to testing equipment in the high pressure injection system. The extension in the surveillance period applies to the current shutdown period only.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.


8108030466 810720
PDR ADCK 05000289
P PDR

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated April 24, 1981 and June 15, 1981, (2) Amendment No. 60 to License No. DPR-50, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. 20555, and at the Government Publications Section, State Library of Pennsylvania, Education Building, Commonwealth and Walnut Streets, Harrisburg, Pennsylvania 17126. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 20th day of July 1981.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing