

October 26, 2000

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNIT 2 - UPCOMING STEAM
GENERATOR TUBE INSERVICE INSPECTION

Dear Mr. Scalice:

Inservice inspections of steam generator (SG) tubes play a vital role in assuring that adequate structural integrity of the tubes is maintained. As required by the plant Technical Specifications, reporting requirements range from submitting a special report, within 15 days following completion of each inservice inspection of SG tubes, that identifies the number of tubes plugged and/or repaired; to submitting a special report, within 12 months following completion of the inspection, that provides complete results of the SG tube inservice inspection. The special report containing the complete results shall include the following:

1. Number and extent of tubes inspected.
2. Location and percent of wall-thickness penetration for each indication of an imperfection.
3. Identification of tubes plugged and/or repaired.

A phone conference has been arranged with members of your staff to discuss the ongoing results of the SG tube inspections to be conducted during the upcoming Sequoyah Nuclear Plant, Unit 2, refueling outage. This phone call will occur after the majority of the tubes have been inspected, but before the SG inspection activities have been completed. Attached is a list of discussion points to facilitate this phone conference.

It is the staff's expectation that any significant results discussed during the phone conference, as well as any materials provided by your staff to assist us during the phone conference in the understanding of the SG tube results, will be included in one of the special reports required by the plant Technical Specifications.

Sincerely,

/RA/

Ronald W. Hernan, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-328

Enclosure: List of Discussion Points

cc w/encl: See next page

October 26, 2000

Mr. J. A. Scalice
Chief Nuclear Officer and
Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNIT 2 - UPCOMING STEAM
GENERATOR TUBE INSERVICE INSPECTION

Dear Mr. Scalice:

Inservice inspections of steam generator (SG) tubes play a vital role in assuring that adequate structural integrity of the tubes is maintained. As required by the plant Technical Specifications, reporting requirements range from submitting a special report, within 15 days following completion of each inservice inspection of SG tubes, that identifies the number of tubes plugged and/or repaired; to submitting a special report, within 12 months following completion of the inspection, that provides complete results of the SG tube inservice inspection. The special report containing the complete results shall include the following:

4. Number and extent of tubes inspected.
5. Location and percent of wall-thickness penetration for each indication of an imperfection.
6. Identification of tubes plugged and/or repaired.

A phone conference has been arranged with members of your staff to discuss the ongoing results of the SG tube inspections to be conducted during the upcoming Sequoyah Nuclear Plant, Unit 2, refueling outage. This phone call will occur after the majority of the tubes have been inspected, but before the SG inspection activities have been completed. Attached is a list of discussion points to facilitate this phone conference.

It is the staff's expectation that any significant results discussed during the phone conference, as well as any materials provided by your staff to assist us during the phone conference in the understanding of the SG tube results, will be included in one of the special reports required by the plant Technical Specifications.

Sincerely,

/RA/

Ronald W. Hernan, Senior Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-328

Enclosure: List of Discussion Points

cc w/encl: See next page

DISTRIBUTION:

Paper Copies

PUBLIC PDII-2 RF BClayton RHernan ESullivan CBeardsley MFields

E-Mail

RidsNrrDlpmLpdii RidsNrrDlpmLpdii2 RidsNrrPMRHernan RidsAcrcAcnwMailCenter
PFredrickson(RidsRgn2MailCenter) RidsOgcRp

Accession Number ML003763995

OFFICE	PDII-2/PM	PDII-2/LA	PDII-2/SC
NAME	RHernan	BClayton	RCorreia
DATE	10/25/00	10/26/00	10/26/00

OFFICIAL RECORD COPY
STEAM GENERATOR TUBE INSPECTION DISCUSSION POINTS

PREPARED BY THE OFFICE OF NUCLEAR REACTOR REGULATION

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT, UNIT 2

DOCKET NO. 50-328

The following discussion points have been prepared to facilitate the phone conference arranged with the Sequoyah licensee to discuss the results of the steam generator (SG) tube inspections to be conducted during the upcoming Sequoyah Nuclear Plant, Unit 2, refueling outage. This phone call is scheduled to occur towards the end of the planned SG tube inspection interval, but before the unit exits its refueling outage.

It is the staff's expectation that any significant results or relevant trends discussed during the phone conference, as well as any materials provided by your staff to assist us in understanding the SG tube results during the phone conference, will be included in one of the special reports required by the plant Technical Specifications.

1. Discuss whether any primary to secondary leakage existed in this unit prior to shutdown.
2. Discuss the results of secondary side hydrostatic tests.
3. For each steam generator, provide a general description of areas examined, including the expansion criteria utilized and type of probe used in each area.
4. For analyzed eddy current results, describe bobbin indications (those not examined with rotating pancake coil (RPC)) and RPC/Plus Point/Cecco indications. Include the following information in the discussion: location, number, degradation mode, disposition, and voltages/depths/lengths of significant indications.
5. Describe repair/plugging plans for the SG tubes that meet the repair/plugging criteria.
6. Discuss the previous history of SG tube inspection results, including any "look backs" performed.
7. Discuss, in general, the new inspection findings.
8. Describe *in situ* pressure test plans and results, if applicable and available, including tube selection criteria.
9. Describe tube pull plans and preliminary results, if applicable and available; include tube selection criteria.
10. Discuss the assessment of tube integrity for the previous operating cycle.
11. Discuss the assessment of tube integrity for next operating cycle .
12. Provide the schedule for SG-related activities during the remainder of the current outage.
13. Discuss what steps have been taken, or will be taken, in response to the lessons learned from the Indian Point Unit 2 tube failure. In addition, please be prepared to discuss the following:
 - a) Actions that are taken in response to identifying a new degradation mechanism, and
 - b) Actions taken to ensure that data noise levels are acceptable, and
 - c) Data quality issues and the need for criteria to address data quality.

Mr. J. A. Scalice
Tennessee Valley Authority

SEQUOYAH NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Russell A. Gibbs
Senior Resident Inspector
Sequoyah Nuclear Plant
U.S. Nuclear Regulatory Commission
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Mr. Jack A. Bailey
Vice President
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Lawrence E. Nanney, Director
Division of Radiological Health
Dept. of Environment & Conservation
Third Floor, L and C Annex
401 Church Street
Nashville, TN 37243-1532

Mr. Richard T. Purcell
Site Vice President
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

County Executive
Hamilton County Courthouse
Chattanooga, TN 37402-2801

Ms. Ann Harris
305 Pickel Road
Ten Mile, TN 37880

General Counsel
Tennessee Valley Authority
ET 10H
400 West Summit Hill Drive
Knoxville, TN 37902

Mr. Robert J. Adney, General Manager
Nuclear Assurance
Tennessee Valley Authority
5M Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Pedro Salas, Manager
Licensing and Industry Affairs
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379

Mr. D. L. Koehl, Plant Manager
Sequoyah Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Soddy Daisy, TN 37379