

AmerGen

A PECO Energy/British Energy Company

AmerGen Energy Company, LLC
Oyster Creek
U.S. Route 9 South
P.O. Box 388
Forked River, NJ 08731-0388
Telephone: 609 971 4000

October 23, 2000
2130-00-20276

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington DC 20555

Dear Sir:

Subject: Oyster Creek Generating Station
Docket No. 50-219
Secondary Containment Capability Results

The Oyster Creek Nuclear Generating Station Technical Specifications require:

- 4.5.G.2 “(Secondary Containment) tests shall be performed at least once per operating cycle...”
- 4.5.G.3 “A secondary containment capability test shall be conducted at each refueling outage prior to refueling.”
- 4.5.G.4 “The results of the secondary containment capability tests shall be in the subject of a summary technical report...”

Attachment I to this letter documents the completion of requirements 4.5.G.2 and 4.5.G.3 by docketing the report required in 4.5.G.4.

If any additional information or assistance is required, please contact Mr. John Rogers of my staff at 609.971.4893.

Very truly yours,



Ron J. DeGregorio, Vice President
Oyster Creek

RJD/JJR
Attachment

cc: Administrator, Region I
NRC Project Manager
Senior Resident Inspector

A001

Attachment I

Summary Technical Report Secondary Containment Capability Test

Oyster Creek Nuclear Generating Station
Operating Cycle 17; Prior to Refueling Outage 18R
Date Performed: September 24, 2000

1. Wind Speed

Test Prerequisite	Observed
"...calm wind..."	14.6 mph

2. Standby Gas Treatment System Flow Rate

Test Requirement	Test Results
< 4000 cfm	2650 cfm

3. Reactor Building Differential Pressure

Test Requirements	Test Results
Both Reactor Airlock Doors Closed	
- 0.25 inches W.G.	- 0.402 inches W.G.
Outer Railroad Airlock Door Open	
- 0.25 inches W.G.	- 0.403 inches W.G.
Inner Railroad Airlock Door Open	
-0.25 inches W.G.	- 0.312 inches W.G.