

SEP 14 1983

DMB 016

MEMORANDUM FOR: James R. Miller, Chief  
Operating Reactors Branch #4, DL

FROM: John F. Stolz, Chief  
Operating Reactors Branch #4, DL

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE -  
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING  
LICENSE AND FINAL DETERMINATION OF NO SIGNIFICANT  
HAZARDS CONSIDERATION (REPEAT OF INDIVIDUAL NOTICE)

GPU Nuclear Corporation, et al., Docket No. 50-289, Three Mile Island  
Nuclear Station, Unit No. 1, Dauphin County, Pennsylvania

Date of application for amendment: May 9, 1983 ✓

Brief description of amendment: The amendment revised the license and  
the Technical Specifications to recognize and approve the steam  
generator tube kinetic expansion repair technique only for purposes  
of steam generator hot functional testing using pump heat (non-nuclear),  
and permits such testing. This amendment is in partial response to  
the May 9, 1983, application.

Date of issuance: August 25, 1983

Effective date: August 25, 1983

Amendment No.: 86

Facility Operating License No.: DPR-50

Date of individual notice in Federal Register: September 1, 1983,

48 FR 39709

ORIGINAL SIGNED BY:  
JOHN F. STOLZ

John F. Stolz, Chief  
Operating Reactors Branch #4, DL

DISTRIBUTION:

Docket File  
ORB #4 Rdg  
Memo File  
RIngram

JVan Vliet  
PDR per JStolz 4/2/84

8309210506 830914  
CF ADOCK 05000289  
CF

OFFICE	ORB #4: DL	ORB #4: DL	ORB #4: DL				
SURNAME	RIngram	JVan Vliet; cf	JStolz				
DATE	9/9/83	9/11/83	9/14/83				