

October 15, 1987

Docket No. 50-289

Mr. Henry D. Hukill, Vice President
and Director - TMI-1
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

Dear Mr. Hukill:

Subject: Issuance of Amendment (TAC # 64698)

The Commission has issued the enclosed Amendment No.133 to Facility Operating License No. DPR-50 for the Three Mile Island Nuclear Station, Unit No. 1 (TMI-1). This amendment consists of changes to the Technical Specifications (TSS) in response to your letter dated February 5, 1987.

This amendment revises TS 3.4.1.2.2 and associated bases, to allow plant operation with a minimum of two operable Main Steam Safety Valves per steam generator when the reactor has been subcritical for at least one hour and the reactor is between hot shutdown and 5% power.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely,
/s/

Gordon E. Edison, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects I/II

Enclosures:

- 1. Amendment No. 133 to DPR-50
- 2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

Docket File	J. Partlow
NRC & Local PDRs	T. Barnhart (4)
PDI-4 Reading	Wanda Jones
S. Varga	E. Butcher
B. Boger	C. Liang
S. Norris	
P. Tam	ACRS (10)
OGC-Bethesda	GPA/PA
D. Hagan	ARM/LFMB
E. Jordan	PD Files

8710230281 871015
PDR ADOCK 05000289
P PDR

LAPDI-4
SNOPPTS
9/9/87

PDI-4 *HEE*
GEdison;eh
9/11/87

PDI-4 *HEE*
JStolz *for*
9/11/87

OGC-Beth *LHZ*
S H Lewis
10/7/87

Mr. Henry D. Hukill
GPU Nuclear Corporation

cc:
Mr. R. J. Toole
O&M Director, TMI-1
GPU Nuclear Corporation
Middletown, Pennsylvania 17057

Richard J. McGoey
Manager, PWR Licensing
GPU Nuclear Corporation
100 Interpace Parkway
Parsippany, New Jersey 70754

Mr. C. W. Smyth
TMI-1 Licensing Manager
GPU Nuclear Corporation
P. O. Box 480
Middletown, Pennsylvania 17057

Ernest L. Blake, Jr., Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037

Sheldon J. Wolfe, Esq., Chairman
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Frederick J. Shon
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Oscar H. Paris
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety & Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Atomic Safety & Licensing Appeal
Board Panel (8)
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docketing and Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Three Mile Island Nuclear Station,
Unit No. 1

Mr. Richard Conte
Senior Resident Inspector (TMI-1)
U.S.N.R.C.
P.O. Box 311
Middletown, Pennsylvania 17057

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Mr. Larry Hochendoner
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Streets
Harrisburg, Pennsylvania 17101

Mr. David D. Maxwell, Chairman
Board of Supervisors
Londonderry Township
RFD#1 - Geyers Church Road
Middletown, Pennsylvania 17057

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Thomas Y. Au, Esq.
Office of Chief Counsel
Department of Environmental Resources
505 Executive House
P. O. Box 2357
Harrisburg, Pennsylvania 17120

Ms. Louise Bradford
TMIA
1011 Green Street
Harrisburg, Pennsylvania 17102

Mr. Henry D. Hukill
GPU Nuclear Corporation

-2-

Three Mile Island Nuclear Station
Unit 1

cc:
TMIA
315 Peffer Street
Harrisburg, Pennsylvania 17102

Bruce W. Churchill, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, D.C. 20037



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

GPU NUCLEAR CORPORATION

DOCKET NO. 50-289

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 133
License No. DPR-50

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation, et al. (the licensee) dated February 5, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8710230299 871015
PDR ADDCK 05000289
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(?) of Facility Operating License No. DPR-50 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 133, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

J F Stolz for

John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 15, 1987

ATTACHMENT TO LICENSE AMENDMENT NO.133

FACILITY OPERATING LICENSE NO. DPR-50

DOCKET NO. 50-289

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

3-26
3-26a
3-26b
3-26c

Insert

3-26
3-26a
3-26b
3-26c

3.4.1.2.1 With the Reactor from 250°F to HOT SHUTDOWN and subcritical for at least one (1) hour, two (2) Main Steam Safety Valves per Steam Generator shall be OPERABLE. With less than two (2) Main Steam Safety Valves per Steam Generator OPERABLE, restore at least two (2) MSS Valves to OPERABLE status for each Steam Generator within 6 hours or be in COLD SHUTDOWN within the following 30 hours.

3.4.1.2.2 With the Reactor from HOT SHUTDOWN to 5% power and having been subcritical for at least one (1) hour, two (2) Main Steam Safety Valves per Steam Generator shall be OPERABLE provided the over power trip setpoint in the RPS is set to less than 5% full power. With less than two (2) Main Steam Safety Valves per Steam Generator OPERABLE, restore at least two (2) MSS Valves to OPERABLE status for each Steam Generator within 6 hours or be in COLD SHUTDOWN within the following 30 hours.

3.4.1.2.3 Except as provided in T.S. 3.4.1.2.2 above, when the Reactor is above HOT SHUTDOWN, all eighteen (18) Main Steam Safety Valves shall be OPERABLE or, if any are not OPERABLE, the maximum overpower trip setpoint (see Table 2.3-1) shall be reset as follows:

<u>Maximum Number of Safety Valves Disabled on Any Steam Generator</u>	<u>Maximum Overpower Trip Setpoint (% of Rated Power)</u>
1	92.4
2	79.4
3	66.3

With more than three (3) Main Steam Safety Valves INOPERABLE, restore at least fifteen (15) Main Steam Safety Valves to OPERABLE status within 4 hours or be in at least HOT SHUTDOWN within the next 6 hours.

3.4.2 Reactor Coolant System temperature 250°F or less.

3.4.2.1 With Reactor Coolant temperature 250°F or less, at least two of the following means for maintaining decay heat removal capability shall be OPERABLE and at least one shall be in operation except as allowed by Specifications 3.4.2.2, 3.4.2.3 and 3.4.2.4.

- a. Decay Heat Removal String "A".
- b. Decay Heat Removal String "B".
- c. Reactor Coolant Loop "A", its associated OTSG, and its associated emergency feedwater flowpath.
- d. Reactor Coolant Loop "B", its associated OTSG, and its associated emergency feedwater flowpath.

- 3.4.2.2 Operation of the means for decay heat removal may be suspended provided the core outlet temperature is maintained below saturation temperature.
- 3.4.2.3 The number of means for decay heat removal required to be operable per 3.4.2.1 may be reduced to one provided that one of the following conditions is satisfied:
- a. The Reactor is in a Refueling Shutdown condition with the Fuel Transfer Canal water level greater than 23 feet above the reactor vessel flange.
 - b. Reactor coolant temperature is less than 140°F with BWST level greater than 44 feet and an associated flow path through the RCS OPERABLE such that core outlet temperature can be maintained subcooled for at least 7 days.
 - c. Equipment Maintenance on one of the means for decay heat removal specified by 3.4.2.1 is required and the equipment outage does not exceed 7 days.
- 3.4.2.4 Specification 3.4.2.1 does not apply when either of the following conditions exist:
- a. Decay heat generation is less than 188 KW with the RCS full.
 - b. Decay heat generation is less than 100 KW with the RCS drained down for maintenance.
- 3.4.2.5 With less than the above required loops OPERABLE, immediately initiate corrective action to return the required loops to OPERABLE status as soon as possible.

Bases

A reactor shutdown following power operation requires removal of core decay heat. Normal decay heat removal is by the steam generators with the steam dump to the condenser when RCS temperature is above 250°F and by the decay heat removal system below 250°F. Core decay heat can be continuously dissipated up to 15 percent of full power via the steam bypass to the condenser as feedwater in the steam generator is converted to steam by heat absorption. Normally, the capability to return feedwater flow to the steam generators is provided by the main feedwater system.

The main steam safety valves will be able to relieve to atmosphere the total steam flow if necessary. Below 5% power, only a minimum number of Main Steam Safety Valves need to be operable as stated in Technical Specification 3.4.1.2.1 and 3.4.1.2.2. This is to provide Steam Generator overpressure protection during hot functional testing and low power physics testing. Additionally, when the Reactor is between hot shutdown and 5% full power operation, the over power trip setpoint in the RPS shall be set to less than 5% as is specified in Technical Specification 3.4.1.2.2. The minimum number of valves required to be operable allows margin for testing without jeopardizing plant safety. Plant specific analysis shows that one Main Steam Safety Valve is sufficient to relieve reactor coolant pump heat and stored energy when the reactor is subcritical by 1% $\Delta K/K$ for at least one hour. Other plant analyses show that two (2) Main Steam Safety Valves on either OTSG are more than sufficient to relieve reactor coolant pump heat and stored energy when the reactor is below 5% full power operation but had been subcritical by 1% $\Delta K/K$ for at least one hour since power operation above 5% full power. According to Technical Specification 3.1.1.2a, both steam generators shall be operable whenever the reactor coolant average temperature is above 250°F. This assures that all four (4) Main Steam Safety Valves are available for redundancy. During power operations at 5% full power or above, if Main Steam Safety Valves are inoperable, the power level must be reduced, as stated in Technical Specification 3.4.1.2.3 such that the remaining safety valves can prevent overpressure on a turbine trip.

In the unlikely event of complete loss of off-site electrical power to the station, decay heat removal is by either the steam-driven emergency feedwater pump, or two half-sized motor-driven pumps. Steam discharge is to the atmosphere via the Main Steam Safety Valves and controlled atmospheric relief valves, and in the case of the turbine driven pump, from the turbine exhaust.(1)

Both motor-driven pumps are required initially to remove decay heat with one eventually sufficing. The minimum amount of water in the condensate storage tanks, contained in Technical Specification 3.4.1.1., will allow cooldown to 250°F with steam being discharged to the atmosphere. After cooling to 250°F, the decay heat removal system is used to achieve further cooling.

When the RCS is below 250°F, a single DHR string, or single OTSG and its associated emergency feedwater flowpath is sufficient to provide removal of decay heat at all times following the cooldown to 250°F. The requirement to maintain two OPERABLE means of decay heat removal ensures that a single failure does not result in a complete loss of decay heat removal capability. The requirement to keep a system in operation as necessary to maintain the system subcooled at the core outlet provides the guidance to ensure that steam conditions which could inhibit core cooling do not occur.

Limited reduction in redundancy is allowed for preventive or corrective maintenance on the primary means for decay heat removal to ensure that maintenance necessary to assure the continued reliability of the systems may be accomplished.

As decay heat loads are reduced through decay time or fuel off loading, alternate flow paths will provide adequate cooling for a time sufficient to take compensatory action if the normal means of heat removal is lost.

With the reactor vessel head removed and 23 feet of water above the reactor vessel flange, a large heat sink is available for core cooling. The BWST with level at 44 feet provides an equivalent reservoir available as a heat sink. Operability of the BWST is to be determined using calculations based on actual plant data or through plant testing at the time the system is to be declared operable. At such times that either of these means is determined to be operable, removal of the redundant or diverse cooling system is permitted.

Following extensive outages or major core off loading, the decay heat generation being removed from the Reactor Vessel is so low that ambient losses are sufficient to maintain core cooling and no other means of heat removal is required. The system is passive and requires no redundant or diverse backup system. Decay heat generation is calculated in accordance with ANSI 5.1-1979 to determine when this situation exists.

An unlimited emergency feedwater supply is available from the river via either of the two motor-driven reactor building emergency cooling water pumps for an indefinite period of time.

The requirements of Technical Specification 3.4.1.1 assure that before the reactor is heated to above 250°F, adequate auxiliary feedwater capability is available. One turbine driven pump full capacity (920 gpm) and the two half-capacity motor-driven pumps (460 gpm each) are specified. However, only one half-capacity motor-driven pump is necessary to supply auxiliary feedwater flow to the steam generators in the onset of a small break loss-of-coolant accident.

REFERENCES

(1) FSAR Section 10.2.1.3



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 133 TO FACILITY OPERATING LICENSE NO. DPR-50

METROPOLITAN EDISON COMPANY
JERSEY CENTRAL POWER AND LIGHT COMPANY
PENNSYLVANIA ELECTRIC COMPANY
GPU NUCLEAR CORPORATION

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1

DOCKET NO. 50-289

1.0 INTRODUCTION

The current Three Mile Island, Unit 1 (TMI-1) Technical Specifications (TS) require that two (2) Main Steam Safety Valves (MSSVs) per steam generator shall be operable when the Reactor Coolant System Temperature is between 250°F and hot shutdown conditions. When the reactor is above hot shutdown condition, all eighteen (18) MSSVs shall be operable.

In a letter dated February 5, 1987, GPU Nuclear Corporation (licensee) stated that the current TS do not provide for efficient in-place testing of MSSVs following valve maintenance during cold shutdown or refueling. The proposed modifications of the TS would allow for a nominal increase in power of no more than 5% while the MSSVs and other functional testing are being performed.

2.0 EVALUATION

The licensee proposed TS Section 3.4.1.2.2 states that with the reactor from HOT SHUTDOWN to 5% power and having been subcritical for at least 1 hour, two Main Steam Safety Valves per Steam Generator shall be OPERABLE provided the over power trip setpoint in the RPS is set to less than 5% full power. With less than two Main Steam Safety Valves per Steam Generator OPERABLE, restore at least two Main Steam Safety Valves to OPERABLE status for each Steam Generator within 6 hours or be in COLD SHUTDOWN within the following 30 hours.

The licensee provided the results of a calculation which demonstrated that two MSSVs on either once through steam generator are more than sufficient to release the amount of steam produced from the reactor decay heat, reactor coolant pump heat and sensible heat from feedwater. The staff has evaluated the assumptions used in the licensee's calculation and find that they are conservative.

According to the proposed TS Section 3.1.1.2a, both steam generators are required to be operable when the reactor coolant average temperature is above 250°F. This TS assures that a total of four MSSVs are available when the reactor is operated up to 5% power. Under these conditions, the total available steam relief capacity is more than two times the calculated minimum requirement.

Based on the above evaluation, the staff concludes that the licensee proposed changes of TS Section 3.4.1.2.2 and its bases on pages 3-26b will ensure sufficient MSSV relieving capacity when the TMI-1 is operated up to 5% power. The proposed TS meet the applicable regulatory guidance and requirements and therefore, are acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

This amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. We have determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: October 15, 1987

Principal Contributor:
C. Liang