

October 27, 2000

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

EPA Permit No. PA0025615 Revised December 1999 DMR Results

Dear Sir:

It has come to my attention that some recipients have not received a copy of the enclosed revised December 1999 DMR letter and report. This revised copy is provided for your information.

Joe Venzon
Chemistry Manager

Attachment

c: T. Cosgrove
Tiffany Shepard
Licensing File
Central File – Keywords: NPDES Reportable Occurrence
DMR Clerk
US NRC Document Control Desk
Lab file copy

IE25

October 5, 2000Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

EPA Permit No. PA0025615 Revised December 1999 DMR Results

Dear Sir:


As required by the EPA Permit No. PA0025615, the following information is provided in regard to a revised DMR submittal for December 1999 at Beaver Valley Power Station.

During the annual visit by PA DEP it was discovered that a TSS in excess of the maximum daily limit for Outfall 008 had been submitted with the permit renewal samples. These results were not included in the monthly DMR submittal because the sample results obtained for the permit renewal were not completed or reviewed prior to the December submittal. Including these values with the sample values reported for December results in a monthly average of 89.6 ppm, which exceeds the monthly average TSS limit.

Tests performed by BVPS personnel in October 2000 confirm that the sampling arrangement used to collect the 24-hour composite sample for permit renewal application in December 1999 consistently results in a large high bias for TSS. Further review of historical TSS data for Outfall 008 does not indicate that a problem with TSS compliance exists at this Outfall.

If you have any questions concerning this report, please contact Joe Venzon at (724) 682-5113.

Sincerely,

Bill Pearce
Plant General Manager

Attachment

JWV/lar

C: T. Cosgrove
Tiffany Shepard
Licensing File
Central File – Keywords: NPDES Reportable Occurrence
DMR Clerk
US NRC Document Control Desk
Lab file copy

FACILITY SHIPPIINGPORT
LOCATION

PA 15077

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
99	12	01	99	12	31

P - FINAL

UNIT 1 COOLING TOWER PUMPHOUS

*** NO DISCHARGE ***
NOTE: Read Instructions before completing this form

ATTN: DAVID ORNDORF

PARAMETER (32-37)	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	(3 Card Only) QUANTITY OR LOADING (46-51)			(4 Card Only) QUANTITY OR CONCENTRATION (38-45) (46-53) (54-61)			NO EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMI TYI (69-71)
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
PH	SAMPLE MEASUREMENT	*****	*****		8.00	*****	8.10	(12)	0	2/31 GRA
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.0	*****	9.0			TWICE/GRAB MONTH
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		*****	87.6 12.5 umc	383 12.6 umc	(19)	0	2/31 GRA
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	30	100			TWICE/GRAB MONTH
OIL & GREASE	SAMPLE MEASUREMENT	*****	*****		<5	<5	<5	(19)	0	2/31 GRA
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	15	20	30			TWICE/GRAB MONTH
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	<0.001	<0.001	(03)	*****	*****	*****		0	1/7 EST
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT NO AVG	REPORT DAILY MX	MGD	*****	*****	*****			WEEKLY EST
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									
	SAMPLE MEASUREMENT									
	PERMIT REQUIREMENT									

NAME TITLE PRINCIPAL EXECUTIVE OFFICER
Revised 10/5/00
 David Orndorf
 Chemistry Manager

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 30 USC 3101 AND 33 USC 3112. Penalties under these statutes may include fines up to \$10,000 and or imprisonment of individuals for up to 5 years.

David Orndorf
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
412 393-7454
AREA CODE NUMBER

DATE
00 10 05
00 01 27
YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 * Revised 10/5/00 to include 24 hour composite results from the permit application.