

SEP 07 1982

DISTRIBUTION:

Docket File R. Ballard  
NRC PDR NSIC  
Local PDR ASLAB  
ORB #1 Rdg.  
D. Eisenhut  
K. Parrish  
P. Tam  
OELD  
SECY  
I&E  
T. Barnhart (4)  
L. Schneider  
D. Brinkman  
ACRS (10)  
OPA (Clare Miles)  
R. Diggs

Docket No. 50-334

Mr. J. J. Carey, Vice President  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, PA 15077

Dear Mr. Carey:

Our letter dated August 2, 1982, transmitted to you Amendment No. 55 to Facility Operating License No. DPR-66 for Beaver Valley Power Station, Unit 1. The Amendment deleted from the Appendix B Technical Specifications the requirement for chlorine sampling.

Due to an administrative error, Page 2-1 was prepared incorrectly. Enclosed please find a revised page. The correction consists of changing the entire section under "Monitoring Requirement" to read "Per requirements in NPDES Permit No. PA0025615".

We apologize for any inconvenience this administrative error may have caused.

Sincerely,

ORIGINAL SIGNED

Peter Tam, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Enclosure:  
Revised TS Page 2-1

cc: w/enclosure  
See next Page

8209230098 820807  
PDR ADDCK 05000334  
P PDR

OFFICE	ORB #1	ORB #1	ORB #1				
SURNAME	Parrish	Tam/tam	Varga				
DATE	9/2/82	9/2/82	9/2/82				



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 7, 1982

Docket No. 50-334

Mr. J. J. Carey, Vice President  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, PA 15077

Dear Mr. Carey:

Our letter dated August 2, 1982, transmitted to you Amendment No. 55 to Facility Operating License No. DPR-66 for Beaver Valley Power Station, Unit 1. The Amendment deleted from the Appendix B Technical Specifications the requirement for chlorine sampling.

Due to an administrative error, Page 2-1 was prepared incorrectly. Enclosed please find a revised page. The correction consists of changing the entire section under "Monitoring Requirement" to read "Per requirements in NPDES Permit No. PA0025615".

We apologize for any inconvenience this administrative error may have caused.

Sincerely,

A handwritten signature in cursive script, reading "Peter S. Tam", is written over the typed name.

Peter Tam, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Enclosure:  
Revised TS Page 2-1

cc: w/enclosure  
See next Page

Mr. J. J. Carey  
Duquesne Light Company

cc: Mr. H. P. Williams  
Station Superintendent  
Duquesne Light Company  
Beaver Valley Power Station  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Mr. T. D. Jones, Manager  
Nuclear Operations  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

B. F. Jones Memorial Library  
663 Franklin Avenue  
Aliquippa, Pennsylvania 15001

Gerald Charnoff, Esquire  
Jay E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, D.C. 20036

Karin Carter, Esquire  
Special Assistant Attorney General  
Bureau of Administrative Enforcement  
5th Floor, Executive House  
Harrisburg, Pennsylvania 17120

Marvin Fein  
Utility Counsel  
City of Pittsburgh  
313 City-County Building  
Pittsburgh, Pennsylvania 15219

Mr. John A. Levin  
Public Utility Commission  
P.O. Box 3265  
Harrisburg, Pennsylvania 17120

Irwin A. Popowsky, Esquire  
Office of Consumer Advocate  
1425 Strawberry Square  
Harrisburg, Pennsylvania 17120

Charles A. Thomas, Esquire  
Thomas and Thomas  
212 Locust Street  
Box 999  
Harrisburg, Pennsylvania 17108

Mr. J. D. Sieber, Manager  
Nuclear Safety and Licensing  
Duquesne Light Company  
Nuclear Division  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Resident Inspector  
U. S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, Pennsylvania 15077

Ronald C. Haynes  
Regional Administrator - Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

2.0 LIMITING CONDITIONS FOR OPERATION

2.1 THERMAL

2.1.1 Maximum Discharge Temperature

Maximum discharge temperature shall be monitored as specified in Section 3.1.

2.2 HYDRAULIC

Not applicable

2.3 CHEMICAL

Objective (General)

To ensure that chemical releases from the station are controlled so as not to adversely affect public health or the natural environment and which are consistent with applicable regulations.

2.3.1. Biocides - (Chlorine)

Objective

To limit the duration of chlorine application to the condenser cooling water and the maximum concentration of free available chlorine in the cooling tower blowdown.

Specification

Concentrations of free available chlorine in the cooling tower blowdown shall not exceed average concentrations of 0.2 mg/l and maximum concentrations of 0.5 mg/l at the discharge structure during a maximum cumulative period of chlorine injection of 2 hours per day.

If levels exceeding that specified above are exceeded, corrective action shall consist of reducing the chlorine injection rate.

Monitoring Requirement

Per NPDES Permit No. PA0025615.