The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

(4) The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans, including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "Oyster Creek Nuclear Generating Station Physical Security Plan," with revisions submitted through July 6, 1988; "Oyster Creek Nuclear Generating Station Training and Qualification Plan," with revisions submitted through June 24, 1986; and "Oyster Creek Nuclear Generating Station Safeguards Contingency Plan," with revisions submitted through June 24, 1986. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.

(5) Inspections of core spray spargers, piping and associated components will be performed in accordance with BWRVIP-18, "BWR Core Spray Internals Inspection and Flaw Evaluation Guidelines," as approved by the NRC staff's Final Safety Evaluation Report dated December 2, 1999.

(6) Long Range Planning Program

The revised "Plan for the Long-Range Planning Program for the Oyster Creek Nuclear Generating Station" (the Plan) submitted by GPUN letter C321-94-2140 dated September 26, 1994, is approved.

a. The Plan shall be followed by the licensee from and after November 28, 1994.

DF04

6.9.3 UNIQUE REPORTING REQUIREMENTS

Special reports shall be submitted to the Director of Regulatory Operations Regional Office within the time period specified for each report. These reports shall be submitted covering the activities identified below pursuant to the requirements of the applicable reference specification.

a. Materials Radiation Surveillance Specimen Reports (4.3A)

b. (Deleted)

c. Results of required leak tests performed on sealed sources if the tests reveal the presence of 0.005 microcuries or more of removable contamination.

d. Deleted

e-j. Pursuant to the ODCM.

k. Records of results of analyses required by the Radiological Environmental Monitoring Program.

l. Failures and challenges to Relief and Safety Valves which do not constitute an LER will be the subject of a special report submitted to the Commission within 60 days of the occurrence. A challenge is defined as any automatic actuation (other than during surveillance or testing) of Safety or Relief Valves.

m. Plans for compliance with standby liquid control Specifications 3.2.C.3(b) and 3.2.C.3(e)(1) or plans to obtain enrichment test results per Specification 4.2.E.5.

n. Inoperable high range radioactive noble gas effluent monitor (3.13.H)