

Docket No. 50-334

DISTRIBUTION

February 27, 1984
Mr. J. J. Carey, Vice President
Nuclear Division
Post Office Box 4
Shippingport, PA 15077

Docket File
L PDR
DEisenhut
CParrish
SECY
EJordan
TBarnhart(4)
DBrinkman

NRC PDR
ORB#1 Rdg
PTam
OELD
LHarmon
JTaylor
WJones
ACRS (10)

OPA CMiles
RDiggs

The Commission has issued the enclosed Amendment No.76 to Facility Operating License No. DPR-66 for the Beaver Valley Power Station, Unit No. 1. The amendment consists of changes to the Technical Specifications in response to your application dated July 14, 1983.

The amendment changes the Technical Specifications by adding six hydraulic snubbers to the surveillance list, Table 3.7-4a.

A copy of the related Safety Evaluation is enclosed. The Notice of Issuance will be included in the Commission's next regular monthly Federal Register notice.

Sincerely,

~~ORIGINAL SIGNATURE~~

Peter Tam, Project Manager
Operating Reactors Branch No. 1
Division of Licensing

Enclosures:

1. Amendments No. 76 to DPR-66
2. Safety Evaluation

cc: w/enclosures
See next page

ORB#1:DL
CParrish
2/13/84

cp

ORB#1:DL
PTam
2/14/84

PT

C-ORB#1:DL
SVarga
2/14/84

[Signature]

OELD
2/12/84

[Signature]

AD, OR-DL
GLaThas
2/27/84

[Signature]

8403070387 840227
PDR ADCK 05000334
P PDR

Mr. J. J. Carey
Duquesne Light Company

Beaver Valley Power Station
Unit 1

cc: Mr. W. S. Lacey
Station Superintendent
Duquesne Light Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15007

Mr. Thomas J. Czerpah
Mayor of the Burrough of
Shippingport
Post Office Box 26
Shippingport, PA 15077

Mr. K. Grada, Superintendent
of Licensing and Compliance
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

Pennsylvania Power Company
Ray E. Sempler
One E. Washington Street
New Castle, PA 16103

Mr. John A. Levin
Public Utility Commission
Post Office Box 3265
Harrisburg, PA 17120

Ohio Environmental Protection Agency
Division of Planning
Environmental Assessment Section
Post Office Box 1049
Columbus, Ohio 43216

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Office of the Governor
State of West Virginia
Charleston, West Virginia 25305

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, PA 17120

Charles A. Thomas, Esquire
Thomas and Thomas
212 Locust Street
Box 999
Harrisburg, PA 17108

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburg, PA 15219

Regional Radiation Representative
EPA Region III
Curtis Building - 6th Floor
Philadelphia, PA 19106

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, PA 15077

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
Post Office Box 1323
Harrisburg, PA 17120

Department of Environmental Resources
ATTN: Director, Office of Radiolo-
gical Health
Post Office Box 2063
Harrisburg, PA 17105

Mr. Joseph H. Mills, Acting Commissioner
State of West Virginia Department
of Labor
1900 Washington Street
East Charleston, West Virginia 25305

Beaver Valley Power Station
Unit 1

- 2 -

cc: N. H. Dyer, M.D.
State Director of Health
State Department of Health
1800 Washington Street, East
Charleston, West Virginia 25305

Irwin A. Popowsky, Esquire
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, PA 17120

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 76
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, Ohio Edison Company, and Pennsylvania Power Company (the licensees) dated July 14, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:


8403070389 840227
PDR ADOCK 05000334
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 76, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 27, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Revise Appendix A as follows:

Remove Page
3/4 7-32i

Insert Page
3/4 7-32i

TABLE 3.7-4a (Continued)

SAFETY RELATED HYDRAULIC SNUBBERS*

| <u>SNUBBER NO.</u> | <u>SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION</u> | <u>ACCESSIBLE OR INACCESSIBLE</u> | <u>HIGH RADIATION ZONE</u> | <u>ESPECIALLY DIFFICULT TO REMOVE</u> |
|--------------------|--|-----------------------------------|----------------------------|---------------------------------------|
| FC-HSS-201 | FC FUEL BUILDING 747' | A | No | No |
| FC-HSS-5A | " " 747' | " | " | " |
| FC-HSS-202 | " " 745' | " | " | " |
| FC-HSS-203 | " " 745' | " | " | " |
| FC-HSS-204 | " " 742' | " | " | " |
| FC-HSS-205 | " " 742' | " | " | " |
| FC-HSS-206 | " " 742' | " | " | " |
| WFPD-HSS-228 | FW CABLE VAULT 761' | A | No | Yes |
| WFPD-HSS-229 | " " 761' | " | " | " |
| WFPD-HSS-230 | " " 761' | " | " | " |
| WFPD-HSS-231 | " " 767' | " | " | " |
| WFPD-HSS-232 | " " 767' | " | " | " |
| WFPD-HSS-233 | " " 767' | " | " | " |

* Snubbers may be added to safety related systems without prior License Amendment to Table 3.7-4 provided that safety evaluations, documentation and reporting are provided in accordance with 10 CFR 50.59 and that a revision to Table 3.7-4 is included with a subsequent License Amendment request.

BEAVER VALLEY - UNIT 1

3/4 7-324

Amendment No. 76



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NO. DPR-66

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

BEAVER VALLEY POWER STATION, UNIT NO. 1

DOCKET NO. 50-334

Introduction

By letter dated July 14, 1983, Duquesne Light Company submitted a request for a proposed amendment to Appendix A of Operating License No. DPR-66 for the Beaver Valley Power Station Unit No. 1. The proposed amendment would add six hydraulic snubbers to the Technical Specifications surveillance list.

Evaluation

These six snubbers are located on the main feedwater system upstream of the auxiliary feedwater piping and were inadvertently omitted from the original Technical Specifications. Since their function is to prevent excessive pipe deflections during a seismic event, these six snubbers should be included in the Technical Specifications surveillance list.

The proposed revision is administrative in nature since it only adds six existing snubbers to the surveillance list. It does not involve physical changes in plant safety related systems, components, or structures. It will not increase the likelihood of a malfunction of safety related equipment, will not increase the consequences of an accident previously analyzed, nor create the possibility of a malfunction different from those previously evaluated in the Final Safety Analysis Report.

ENVIRONMENTAL CONSIDERATION

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact,

8403070391 840227
PDR ADDCK 05000334
P PDR

and pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense or security or to the health and safety of the public.

Dated: February 27, 1984

Principal Contributor:
H. Shaw