

July 24, 1985

Docket No. 50-334

Mr. J. J. Carey, Vice President
Nuclear Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

<u>Distribution</u>	Docket file
NRC PDR	L PDR
ORB#1 RDG	Gray file
HThompson	OELD
CParrish	PTam
LHarmon	EJrodan
BGrimes	JPartlow
TBarnhart (4)	WJones
MVirgilio	ACRS (10)
OPA, CMiles	RDiggs

Dear Mr. Carey:

SUBJECT: CORRECTION OF ADMINISTRATIVE ERROR IN AMENDMENT No. 94 (LICENSING ACTION TAC No. 57289)

By letter dated July 5, 1985, we issued Amendment No. 94 to the Beaver Valley Unit 1 license as a result of your request dated March 21, 1985. Subsequent to the issuance, we noted that the "Action" statement on Page 3/4 7-13 has been inadvertently modified. It is not our intent to modify that statement.

Enclosed please find a corrected Page 3/4 7-13.

Sincerely,

/s/PSTam

Peter S. Tam, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish *cp*
07/24/85

ORB#1:DL
PTam/ts *PST*
07/24/85

BC-ORB#1:DL
SVatga
07/24/85

B508090030 B50724
PDR ADDCK 05000334
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 24, 1985

Docket No. 50-334

Mr. J. J. Carey, Vice President
Nuclear Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

Dear Mr. Carey:

SUBJECT: CORRECTION OF ADMINISTRATIVE ERROR IN AMENDMENT No. 94 (LICENSING ACTION TAC No. 57289)

By letter dated July 5, 1985, we issued Amendment No. 94 to the Beaver Valley Unit 1 license as a result of your request dated March 21, 1985. Subsequent to the issuance, we noted that the "Action" statement on Page 3/4 7-13 has been inadvertently modified. It is not our intent to modify that statement.

Enclosed please find a corrected Page 3/4 7-13.

Sincerely,

A handwritten signature in cursive script that reads "Peter S. Tam".

Peter S. Tam, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. J. J. Carey
Duquesne Light Company

Beaver Valley 1 Power Station

cc:

Mr. W. S. Lacey
Station Superintendent
Duquesne Light Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, Pennsylvania 15007

Mr. Thomas J. Czerpah
Mayor of the Burrough of
Shippingport
Post Office Box 26
Shippingport, Pennsylvania 15077

Mr. K. Grada, Superintendent
of Licensing and Compliance
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Pennsylvania Power Company
Ray E. Sempler
One E. Washington Street
New Castle, Pennsylvania 16103

Mr. John A. Levin
Public Utility Commission
Post Office Box 3265
Harrisburg, Pennsylvania 17120

Ohio Environmental Protection Agency
Division of Planning
Environmental Assessment Section
Post Office Box 1049
Columbus, Ohio 43216

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Office of the Governor
State of West Virginia
Charleston, West Virginia 25305

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Charles A. Thomas, Esquire
Thomas and Thomas
212 Locust Street
Box 999
Harrisburg, Pennsylvania 17108

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburg, Pennsylvania 15219

Irwin A. Popwsky, Esquire
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, Pennsylvania 15077

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
Post Office Box 1323
Harrisburg, Pennsylvania 17120

Department of Environmental Resources
ATTN: Director, Office of
Radiological Health
Post Office Box 2063
Harrisburg, Pennsylvania 17105

Mr. Jess T. Shumate, Commissioner
State of West Virginia Department
of Labor
1900 Washington Street, East
Charleston, West Virginia 25305

Duquesne Light Company

- 2 -

Beaver Valley 1 Power Station

cc:

David K. Heydinger, M.D.
State Director of Health
State Department of Health
1800 Washington Street, East
Charleston, West Virginia 25305

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, Pennsylvania 17120

PLANT SYSTEMS

3/4.7.4 REACTOR PLANT RIVER WATER SYSTEM (RPRWS)

LIMITING CONDITION FOR OPERATION

3.7.4.1 At least two reactor plant river water subsystems supplying safety related equipment shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With less than two RPRWS subsystems OPERABLE, restore at least two subsystems to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.4.1 At least two RPRW subsystems shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by:
 1. Verifying that each pump develops the required differential pressure and flow rate when tested in accordance with the requirements of Section 4.0.5.
 2. Cycling each testable power operated or automatic valve servicing safety related equipment through at least one complete cycle of full travel.
 3. Verifying that each valve (manual, power operated or automatic) servicing safety related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 18 months during shutdown, by cycling each power operated valve servicing safety related equipment that is not testable during plant operation, through at least one complete cycle of full travel.