

April 3, 1989

Docket No. 50-334

Mr. J. D. Sieber, Vice President  
Nuclear Group  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

DISTRIBUTION

Docket File	OGC
NRC & Local PDRs	EJordan
Plant File	BGrimes
GLainas	TMeek(4)
BBoger	ACRS(10)
SNorris	DHagan
PTam	WJones
GPA/PA	EButcher
	ARM/LFMB

Dear Mr. Sieber:

SUBJECT: BEAVER VALLEY UNIT 1 - ISSUANCE OF AMENDMENT (TAC NO. 66618)

The Commission has issued the enclosed Amendment No. 138 to Facility Operating License No. DPR-66 for the Beaver Valley Power Station, Unit No. 1, in response to your application dated November 12, 1987, and supplement dated January 1989 (exact date not known).

The amendment revises the applicable engineered safety feature response times specified in Table 3.5-5 to include the time required for suction switchover from the volume control tank to the refueling water storage tank.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance has been forwarded to the Office of the Federal Register for publication.

Sincerely,

*Signed by*

Peter S. Tam, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 138 to DPR-66
2. Safety Evaluation

cc w/enclosures:  
See next page

*DF01*  
*1/0*

LA:PDI-4  
SNorris  
03/17/89

PM:PDI-4  
PTam:cb *PST*  
03/17/89

PD:PDI-4  
JStolz  
*03/13/89*

OGC *NPR*  
W.ROMNEY  
*3/27/89*

*CPH*  
SRXB  
W.HODGES  
*3/17/89*

*must with changes as indicated*  
*Hodges' comments have been incorporated into safety evaluation.*  
*PST 3/17/89*

8904130384 890403  
PDR ADDCK 05000334  
P PDC