

March 13, 1989

MEMORANDUM FOR: Sholly Coordinator

DISTRIBUTION  
Docket File/SNorris  
PTam PDI-4 Rdg File  
OGC (infor only)

FROM: Peter S. Tam, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects I/II

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE OF  
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE  
(TAC NOS. 45114 AND 69364)

Duquesne Light Company, Docket No. 50-334, Beaver Valley Power Station,  
Unit No. 1, Shippingport, Pennsylvania

Date of application for amendment: September 7, 1988

Brief description of amendment: The amendment imposes requirements on the  
incore thermocouples, and the reactor vessel level indicating system (RVLIS).  
In addition, the existing specification on the subcooling margin monitor is  
revised to require at least one channel operable (from zero required).

Date of issuance: March 13, 1989

Effective date: March 13, 1989

Amendment No. 137

Facility Operating License No. DPR-66. Amendment revised the Technical  
Specifications.

Date of initial notice in FEDERAL REGISTER: October 19, 1988 (53 FR 40985)

The Commission's related evaluation of the amendment is contained in a  
Safety Evaluation dated March 13, 1989

No significant hazards consideration comments received: No

Local Public Document Room location: B. F. Jones Memorial Library, 663  
Franklin Avenue, Aliquippa, Pennsylvania 15001.

8903200056 890313  
PDR ADDCK 05000334  
P PNU

Peter S. Tam, Senior Project Manager  
Project Directorate I-4  
Division of Reactor Projects I/II

LA:PDI-4  
SNorris  
02/22/89

PM:PDI-4  
PTam:lmj  
02/22/89

PD:PDI-4  
JStoniz  
02/22/89

OGC  
BmCondonick  
02/27/89

*[Handwritten signature]*  
1/0 *[Handwritten signature]*