
Document Update Notification

COPYHOLDER NO: **TRM-U2-102**

TO: **NRC**

ADDRESS: **DOCUMENT CONTROL, WASHINGTON,
D.C. 20555**

DOCUMENT NO: **TRM-U2**

TITLE: **TECHNICAL REQUIREMENTS MANUAL
(UNIT 2)**

REVISION NO: **005**

CHANGE NO: **AP-05**

SUBJECT: **CONTROLLED DOCUMENT**



If this box is checked, please sign, date, and return.



ANO-1 Docket 50-313



ANO-2 Docket 50-368

Signature

Date

A001

ATTACHMENT TO REVISION NO. 5

FOR ANO- 2

TECHNICAL REQUIREMENTS MANUAL (TRM)

Revise the following pages of the TRM for ANO-2 with the attached pages. The revised pages are identified by Revision number and contain vertical lines indicating the area of change.

REMOVE PAGES

3.3-4
3.9-1

INSERT PAGES

3.3-4
6.9-1

INSTRUMENTATION

SEISMIC INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.3 The seismic monitoring instrumentation shown in Table 3.3-7 shall be OPERABLE.

APPLICABILITY: At all times.

ACTION:

- a. With one or more seismic monitoring instruments inoperable for more than 30 days, immediately initiate a condition report to document the condition and determine any limitations for continued operation of the plant.
- b. The provisions of Technical Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.3.1 Each of the above seismic monitoring instruments shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3-4.

4.3.3.3.2 Each of the above seismic monitoring instruments actuated during a seismic event shall be restored to OPERABLE status within 24 hours and a CHANNEL CALIBRATION performed within 5 days following the seismic event. Data shall be retrieved from actuated instruments and analyzed to determine the magnitude of the vibratory ground motion.

ADMINISTRATIVE CONTROLS

6.9 Reporting Requirements

6.9.2 Special Report

A special report shall be submitted to the Administrator of the Regional Office within the time period specified for inoperable meteorological monitoring instrumentation pursuant to Technical Requirement 3.3.3.4.