

June 12, 1985

Docket No. 50-334

DISTRIBUTION

Docket File

L PDR
Gray File
PTam
OELD
EJordan
JPartlow
WJones
ACRS 10
RDiggs

NRC PDR
ORB#1 Rdg
HThompson
CParrish
LHarmon
BGrimes
TBarnhart 4
MVirgilio
CMiles
RBallard

Mr. J. J. Carey, Vice President
Nuclear Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

Dear Mr. Carey:

SUBJECT: CORRECTION OF ADMINISTRATIVE ERROR FOR AMENDMENT NO. 83
(LICENSING ACTION TAC 52071)

By letter dated November 13, 1984 we issued Amendment No. 83 to the Beaver Valley Unit 1 License No. DPR-66. Recently, your Quality Assurance staff discovered an administrative error in the amendment and informed us of it.

Enclosed please find a revised Page 2-7a. We apologize for any inconvenience and wish to thank your Quality Assurance staff for their careful work.

/s/PTam

Peter S. Tam, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
6/11/85

ORB#1:DL
PTams;ps
6/17/85

BC-ORB#1:DL
SVarga
6/21/85

Mr. J. J. Carey
Duquesne Light Company

cc:

Mr. W. S. Lacey
Station Superintendent
Duquesne Light Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, Pennsylvania 15007

Mr. K. Grada, Superintendent
of Licensing and Compliance
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. John A. Levin
Public Utility Commission
Post Office Box 3265
Harrisburg, Pennsylvania 17120

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburg, Pennsylvania 15219

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, Pennsylvania 15077

Department of Environmental Resources
ATTN: Director, Office of
Radiological Health
Post Office Box 2063
Harrisburg, Pennsylvania 17105

Beaver Valley 1 Power Station

Mr. Thomas J. Czerpah
Mayor of the Burrough of
Shippingport
Post Office Box 26
Shippingport, Pennsylvania 15077

Pennsylvania Power Company
Ray E. Sempler
One E. Washington Street
New Castle, Pennsylvania 16103

Ohio Environmental Protection Agency
Division of Planning
Environmental Assessment Section
Post Office Box 1049
Columbus, Ohio 43216

Office of the Governor
State of West Virginia
Charleston, West Virginia 25305

Charles A. Thomas, Esquire
Thomas and Thomas
212 Locust Street
Box 999
Harrisburg, Pennsylvania 17108

Irwin A. Popwsky, Equire
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Governor's Office of State Planning -
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
Post Office Box 1323
Harrisburg, Pennsylvania 17120

Mr. Jess T. Shumate, Commissioner
State of West Virginia Department
of Labor
1900 Washington Street, East
Charleston, West Virginia 25305

Duquesne Light Company

- 2 -

Beaver Valley 1 Power Station

cc:

David K. Heydinger, M.D.
State Director of Health
State Department of Health
1800 Washington Street, East
Charleston, West Virginia 25305

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, Pennsylvania 17120

TABLE 2.2-1 (Continued)
REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINT

20. (Continued)

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
B. Power Range Neutron Flux, P-8	$\leq 30\%$ RATED THERMAL POWER	$\leq 31\%$ RATED THERMAL POWER
C. Power Range Neutron Flux, P-9	$\leq 49\%$ RATED THERMAL POWER	$\leq 51\%$ RATED THERMAL POWER
D. Power Range Neutron Flux, P-10 (Input to P-7)	10% RATED THERMAL POWER	$>9\%$ and $<12\%$ RATED THERMAL POWER
E. Turbine Impulse Chamber Pressure, P-13 (Input to P-7)	≤ 66 PSIG	≤ 72 PSIG

BEAVER VALLEY - UNIT 1
 8507010514 850612
 PDR ADDCK 05000334
 PDR

2-7a

Amendment No. 83
 Revised by Letter dated June 12, 1985