

DISTRIBUTION

Docket File ✓

ASLAB

NRC PDR

Local PDR

ORB 1 File

D. Eisenhut

C. Parrish

P. Tam

OELD

~~XXXX~~

L. J. Harmon (1)

T. Barnhart (4)

Wanda Jones

D. Brinkman

ACRS (10)

OPA (Clare Miles)

R. Ferguson

R. Diggs

NSIC

APR 18 1983

Docket No. 50-334

Mr. J. J. Carey, Vice President
Duquesne Light Company
Nuclear Division
Post Office Box 4
Shippingport, Pennsylvania 15077

Dear Mr. Carey:

SUBJECT: CORRECTION OF ADMINISTRATIVE ERROR IN AMENDMENT NO. 28, DATED AUGUST 27, 1980

On April 12, 1983, R. Ireland of your staff called me to point out an administrative error in the subject amendment: Part C on your proposed change page 3/4 6-16 was inadvertently omitted in the amendment.

Enclosed please find a revised page 3/4 6-16. We apologize for any inconvenience this error may have caused you.

Sincerely,

Peter S. Tam, Project Manager
Operating Reactors Branch No. 1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

8304270043 830418
PDR ADDCK 05000334
P PDR

OFFICE	ORB 1	ORB 1	ORB 1				
SURNAME	CParrish/rs	PTam/rs	STam/ga				
DATE	4/16/83	4/15/83	4/18/83				

Mr. J. J. Carey
Duquesne Light Company

cc: Mr. W. S. Lacey
Station Superintendent
Duquesne Light Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. K. Grada, Superintendent
of Licensing and Compliance
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. John A. Levin
Public Utility Commission
P.O. Box 3265
Harrisburg, Pennsylvania 17120

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburgh, Pennsylvania 15219

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, Pennsylvania 15077

Department of Environmental
Resources
ATTN: Director, Office of
Radiological Health
Post Office Box 2063
Harrisburg, Pennsylvania 17105

Mr. Thomas J. Czerpah
Mayor of the Burrough of
Shippingport
P.O. Box 26
Shippingport, Pennsylvania 15077

Pennsylvania Power Company
Ray E. Sempler
One E. Washington Street
New Castle, Pennsylvania 16103

Ohio Environmental Protection Agency
Division of Planning
Environmental Assessment Section
P.O. Box 1049
Columbus, Ohio 43216

Office of the Governor
State of West Virginia
Charleston, West Virginia 25305

Charles A. Thomas, Esquire
Thomas and Thomas
212 Locust Street
Box 999
Harrisburg, West Virginia 17108

Mr. J. J. Carey
Duquesne Light Company

cc: Regional Radiation Representatives
EPA Region III
Curtis Building - 6th Floor
Philadelphia, Pennsylvania 19106

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
P.O. Box 1323
Harrisburg, Pennsylvania 17120

Mr. Joseph H. Mills, Acting Commissioner
State of West Virginia Department
of Labor
1900 Washington Street
East Charleston, West Virginia 25305

N. H. Dyer, M.D.
State Director of Health
State Department of Health
1800 Washington Street, East
Charleston, West Virginia 25305

Irwin A. Popowsky, Esquire
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Regional Administrator - Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

c. At least once per 6 months by:

1. Verifying the contained solution volume in the tank, and
2. Verifying the concentration of the NaOH solution by chemical analysis.

d. At least once per 18 months, during shutdown, by:

1. Cycling each valve in the chemical addition system flow path that is not testable during plant operation, through at least one complete cycle of full travel.
2. Verifying that each automatic valve in the flow path actuates to its correct position on a test signal.