



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

October 17, 1997

Mr. J. E. Cross  
President-Generation Group  
Duquesne Light Company  
Post Office Box 4  
Shippingport, PA 15077

SUBJECT: CLARIFICATION OF SAFETY EVALUATION FOR AMENDMENT NO. 206 TO FACILITY  
OPERATING LICENSE NO. DPR-66 AND AMENDMENT NO. 85 TO FACILITY  
OPERATING LICENSE NO. NPF-73, BEAVER VALLEY POWER STATION, UNIT NOS.  
1 AND 2 (TAC NOS. M96622 AND M96623)

Dear Mr. Cross:

By letter dated September 18, 1997, the NRC issued Amendment No. 206 to Facility Operating License No. DPR-66 and Amendment No. 85 to Facility Operating License No. NPF-73 for the Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and BVPS-2). These amendments revised several technical specifications associated with the auxiliary feedwater (AFW) system for both units. Enclosure 3 to that letter provided the NRC staff's safety evaluation and its basis for approval of those amendments. In that evaluation, the NRC staff provided a description of the AFW system for both units as follows:

"The AFW system for each unit includes one steam turbine-driven (TD) pump and two motor-driven (MD) pumps, with the TD pump having twice the capacity of each MD pump. The TD pump for BVPS-1 can receive steam from two of the three main steam lines upstream of the main steam isolation valves (MSIVs). The TD pump for BVPS-2 can receive steam from all three main steam lines upstream of the MSIVs. For both BVPS-1 and BVPS-2, two operable steam supplies are necessary to meet all design basis events concurrent with the worst case single active failure. The AFW pump discharge headers are connected in such a fashion to permit AFW delivery to any one, two, or all three steam generators (SGs). AFW is ultimately fed to the SGs via three main feedwater injection (MFW) headers, downstream of the MFW isolation valves. There are two AFW supply headers (Trains A and B), each feeding all three MFW injection headers via individual motor operated valves (MOV) such that there are a total of six MOVs, three associated with Train A and three associated with Train B. Normally, the Train A MD pump is lined up to the Train A supply header, with the Train B MD pump lined up to the Train B supply header. The TD pump is normally lined up to either one of the two supply headers. In this manner each of the three pumps is normally lined up to automatically feed all three SGs. Each pump has the capability to be lined up to either or both of the AFW supply headers through manually controlled valves at the discharge of each pump. Each AFW pump normally takes suction from the seismic Category I demineralized water storage tank (WT-TK-10 for Unit 1, and TK-210 for Unit 2) via independent suction lines."

1/0  
DFO

9710290234 971017  
PDR ADOCK 05000334  
P PDR



October 17, 1997

As a matter of clarification, the next to last sentence which describes the capability of each pump (two motor-driven and one turbine-driven pump) to be lined up to either or both supply headers only applies to BVPS-1. For BVPS-2, only the turbine-driven pump can be lined up to either or both supply headers. The cross-connect feature of the motor-driven pumps at BVPS-1 did not provide a basis for any of the NRC staff's conclusions regarding the acceptability of the technical specifications of the AFW system design. Therefore, the NRC staff's conclusions set forth in the safety evaluation are unaffected by this clarification.

We apologize for any inconvenience caused by this matter.

Sincerely,



Donald S. Brinkman, Senior Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

cc: See next page

October 17, 1997

As a matter of clarification, the next to last sentence which describes the capability of each pump (two motor-driven and one turbine-driven pump) to be lined up to either or both supply headers only applies to BVPS-1. For BVPS-2, only the turbine-driven pump can be lined up to either or both supply headers. The cross-connect feature of the motor-driven pumps at BVPS-1 did not provide a basis for any of the NRC staff's conclusions regarding the acceptability of the technical specifications of the AFW system design. Therefore, the NRC staff's conclusions set forth in the safety evaluation are unaffected by this clarification.

We apologize for any inconvenience caused by this matter.

Sincerely,

/s/

Donald S. Brinkman, Senior Project Manager  
Project Directorate I-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

cc: See next page

**DISTRIBUTION:**

~~Docket File~~

PUBLIC  
PDI-2 r/f  
BBoger  
JStolz  
MO'Brien(2)  
GHill(4)  
GHubbard  
WBeckner  
WLeFave  
LMarsh  
DBrinkman  
OGC  
ACRS  
PEselgroth, RI

*CMH*

OFFICE	PDI-2/PM <i>DAB</i>	PDI-2/IA <i>[Signature]</i>	OGC	PDI-2/D	
NAME	DBrinkman:cw	MO'Brien	<i>C. Marco</i>	JStolz	
DATE	10/3/97	10/2/97	10/14/97	10/17/97	

OFFICIAL RECORD COPY

DOCUMENT NAME: BVERRATA.LTR

J. E. Cross  
Duquesne Light Company

Beaver Valley Power Station  
Units 1 & 2

cc:

Jay E. Silberg, Esquire  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, NW.  
Washington, DC 20037

Director-Safety and Licensing  
Department (BV-A)  
Duquesne Light Company  
Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077

Commissioner Roy M. Smith  
West Virginia Department of Labor  
Building 3, Room 319  
Capitol Complex  
Charleston, WVA 25305

Director, Utilities Department  
Public Utilities Commission  
180 East Broad Street  
Columbus, OH 43266-0573

Director, Pennsylvania Emergency  
Management Agency  
Post Office Box 3321  
Harrisburg, PA 17105-3321

Ohio EPA-DERR  
ATTN: Zack A. Clayton  
Post Office Box 1049  
Columbus, OH 43266-0149

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Duquesne Light Company  
Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077  
ATTN: R. L. Grand, Division Vice  
President, Nuclear Operations Group  
and Plant Manager (BV-SOSB-7)

Bureau of Radiation Protection  
Pennsylvania Department of  
Environmental Resources  
ATTN: Michael P. Murphy  
Post Office Box 2063  
Harrisburg, PA 17120

Mayor of the Borough of  
Shippingport  
Post Office Box 3  
Shippingport, PA 15077

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 298  
Shippingport, PA 15077

Duquesne Light Company  
Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077  
ATTN: S. C. Jain, Vice President  
Nuclear Services (BV-A)