



Duane Arnold Energy Center  
3313 DAEC Road  
Palo, IA 52324-9646

Operated by Nuclear Management Company, LLC

November 10, 2000


NG-00-1887

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station 0-P1-17  
Washington, DC 20555-0001

Subject: Duane Arnold Energy Center  
Docket No: 50-331  
Operating License: DPR-49  
October 2000 Monthly Operating Report  
File: A-118d

Please find enclosed the Duane Arnold Energy Center Monthly Operating Report for October 2000. The report has been prepared in accordance with the guidelines of NRC Generic Letter 97-02: Revised Contents Of The Monthly Operating Report, and distribution has been made in accordance with DAEC Technical Specifications, Section 5.6.4.

Very truly yours,

  
Rob Anderson  
Plant Manager-Nuclear

RA/RBW

Enclosures

In accordance with DAEC Technical Specifications, Section 5.6.4,  
97-02: Revised Contents Of The Monthly Operating Report and distribution has been made  
The report has been prepared in accordance with the guidelines of NRC Generic Letter  
97-02: Revised Contents Of The Monthly Operating Report and distribution has been made  
The report has been prepared in accordance with the guidelines of NRC Generic Letter  
97-02: Revised Contents Of The Monthly Operating Report and distribution has been made

JE24

NG-00-1887

November 10, 2000

Page 2 of 2

cc:

Mr. James E. Dyer  
Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60532-4351

Ms. Lisa Stump  
Iowa State Utilities Board  
Lucas State Office Building  
Des Moines, IA 50319

Ms. Barbara Lewis  
McGraw-Hill, Inc.  
1200 G Street NW, Suite 1100  
Washington, DC 20005

Dr. William A. Jacobs, Jr.  
GDS Associates, Inc.  
1850 Parkway Place, Suite 720  
Marietta, GA 30068-8237

Mr. Dennis Murdock  
Central Iowa Power Cooperative  
Box 2517  
Cedar Rapids, IA 52406

Mr. Dale Arends  
Corn Belt Power Cooperative  
1300 13th Street North  
Humboldt, IA 50548

Document Control Desk  
INPO Records Center  
700 Galleria Parkway  
Atlanta, GA 30339-5957

Mr. Al Gutterman  
Morgan, Lewis, Bockius  
1800 M St. NW  
Washington, DC 20036-5859

Ms. Brenda Mozafari  
Project Manager  
1 White Flint North  
Mail Stop 13D18  
11555 Rockville Pike  
Rockville, MD 20852

DOCU

NRC Resident Inspector


CTS Project

## OPERATING DATA REPORT

DOCKET NO: 50-331  
 DATE: 11/10/2000  
 Unit: Duane Arnold Energy Center  
 COMPLETED BY: Richard Woodward  
 TELEPHONE: (319) 851-7318

### OPERATING STATUS

1. Unit Name: Duane Arnold Energy Center
2. Reporting Period: October 2000
3. Licensed Thermal Power ( $MW_{th}$ ): 1658
4. Nameplate Rating (Gross  $MW_e$  DER): 565.7 (Turbine)
5. Design Electrical Rating (Net  $MW_e$  DER): 538
6. Maximum Dependable Capacity (Gross  $MW_e$  MDC): 550
7. Maximum Dependable Capacity (Net  $MW_e$  MDC): 520
8. If Changes Occur in Capacity Ratings (Items Number 3 through 7) since the last report, Give Reasons: Not Applicable
9. Power Level to Which Restricted, If Any (Net  $MW_e$ ): N/A
10. Reasons for Restrictions, If Any: N/A



	October-00	2000	Cumulative
11. Hours in Reporting Period	745.0	7,320.0	225,720.0
12. Number of Hours Reactor Was Critical	745.0	7,179.6	176,917.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	745.0	7,090.4	172,986.2
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1,204,948.5	11,612,933.1	250,003,298.1
17. Gross Electrical Energy Generated (MWH)	404,935.0	3,892,468.0	83,820,329.6
18. Net Electrical Energy Generated (MWH)	382,208.7	3,676,516.7	78,735,800.8
19. Unit Service Factor	100.0%	96.9%	76.6%
20. Unit Availability Factor	100.0%	96.9%	76.6%
21. Unit Capacity Factor (Using MDC Net)	98.7%	96.6%	73.3%
22. Unit Capacity Factor (Using DER Net)	95.4%	93.4%	70.1%
23. Unit Forced Outage Rate	0.0%	3.1%	8.8%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each): Refueling Outage 17, April 13, 2001, 40 days
25. If Shutdown at End of Report Period, Estimated Date of Startup: N/A

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-331

DATE: 11/10/2000

Unit: Duane Arnold Energy Center

COMPLETED BY: Richard Woodward

TELEPHONE: (319) 851-7318

MONTH October 2000

Day	Average Daily Power Level (MWe-Net)
1	523.1
2	523.2
3	528.2
4	530.9
5	529.4
6	534.4
7	535.7
8	535.4
9	535.4
10	538.4
11	528.5
12	526.3
13	523.3
14	521.8
15	528.3
16	529.1
17	528.6
18	527.0
19	523.7
20	510.4
21	198.7
22	448.8
23	518.9
24	519.2
25	518.6
26	521.2
27	525.9
28	527.8
29	524.8
30	517.5
31	521.3

DOCKET NO: 50-331  
DATE: 11/10/2000  
Unit: Duane Arnold Energy Center  
COMPLETED BY: Richard Woodward  
TELEPHONE: (319) 851-7318

UNIT SHUTDOWNS AND POWER REDUCTIONS REPORT MONTH: October 2000							
No.	Date	Type (1)	Duration (Hours)	Reason (2)	Method of Shutting Down Reactor (3)	Licensee Event Report #	Cause
9	10/20 21:09 - 10/24 10:15	S	0 (17.39 full- power-hours equivalent)	B	5		Sequence Exchange, Turbine Valve Testing, Recirc Pump Motor Generator brush replacement

1 - F: Forced S: Scheduled	2 - Reason A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)	3 - Method: 1-Manual 2-Manual Scram 3-Automatic Scram 4-Continued 5-Reduced Load 9-Other (Explain)
-------------------------------	--	--

DOCKET NO.: 50-331  
DATE: 11/10/2000  
Unit: Duane Arnold Energy Center  
COMPLETED BY: Richard Woodward  
TELEPHONE: (319) 851-7318

### Monthly Operational Overview for October 2000

For the first nineteen days of the month the DAEC operated nearly continuously at 100% licensed rated power except for two brief 1% – 2% power reductions on October 6<sup>th</sup> and 12<sup>th</sup> to perform control rod drive exercises.

Beginning at 21:09 on October 20<sup>th</sup> recirculation flow was decreased to 60% power to commence a control rod sequence exchange lasting from 22:20 until 04:20 on October 21<sup>st</sup>. At 04:30 on October 21<sup>st</sup>, Main Steam Isolation Valve (MSIV) testing was performed. At 08:30 power was reduced to 35% for approximately six hours to enter into single-recirculation loop operation in order to replace brushes on the 'A' Recirculation Pump motor generator. On October 22<sup>nd</sup>, quarterly turbine valve testing and bypass valve testing were satisfactorily completed. Power was first returned to 100% at 10:14 on October 22<sup>nd</sup>, however approximately seven additional control rod and reactor recirculation pump reactivity manipulations (the last of which was completed at 10:15 on October 24<sup>th</sup>) were required to achieve the target rod pattern. In total, approximately two dozen separate reactivity manipulations were required during this evolution.

At 00:28 on October 29<sup>th</sup> power was reduced approximately 2% when the plant process computer was removed from service in order to reset its clock from daylight-savings to standard time. At 09:25 on October 30<sup>th</sup> power was again reduced approximately 17 hours to remove the plant process computer from service for planned hardware and software maintenance.

Allocation of Production & Losses: October 2000			
	Electrical Output MWe	Capacity Factor % of 571 MWe (Target Output)	Full Power Equivalent Hours (FPHeq)
<b>Capacity Losses:</b>			
Rod Sequence Exchange and CRD adjustments: 10/20 21:09 - 10/24 10:15	13.33	2.33%	17.39
Control Rod Exercises: 10/06 21:06 - 22:42 & 10/14 00:15 - 01:44	0.02	0.00%	0.03
Plant Process Computer, date change and maintenance: 10/29 00:28 - 04:55 & 10/30 09:25 - 10/31 02:00	0.40	0.07%	0.52
Maintain Margin to 1658 MWth Limit	0.25	0.04%	0.33
<b>Efficiency Losses:</b>			
Circ Water System Flow Limitation	2.38	0.42%	3.03
Cooling Tower Low Flow condition	1.42	0.25%	1.86
Steam Cycle Isolation Valve Losses: BV-1	2.30	0.40%	2.98
Other steam cycle isolation losses	0.60	0.11%	0.82
Unidentified Losses	0.00	0.00%	0.00
<b>Average Weather Losses:</b>	<b>+6.77</b>	<b>+1.19%</b>	<b>+8.87</b>
<b>Total On-line Losses:</b>	<b>27.47</b>	<b>4.81%</b>	<b>35.83</b>
<b>Off-Line Losses:</b>	<b>0.00</b>	<b>0.00%</b>	<b>0.00</b>
<b>Electric Generation:</b>			
Plant House Loads (while on-line)	30.49	5.34%	39.80
<b>Net Electric Output</b>	<b>+513.04</b>	<b>+89.85%</b>	<b>+669.37</b>
<b>Gross Electric Generation</b>	<b>543.53</b>	<b>95.19%</b>	<b>709.17</b>
<b>Target Electric Output, Total %, Total # of clock-hours</b>	<b>571.00</b>	<b>100.00%</b>	<b>745.00</b>

(There were no Licensee event reports.)

#### Licensing Action Summary:

Plant Availability:	100.0%	Unplanned Auto Scrams (while critical) this month:	0
Number of reportable events:	0	Unplanned Auto Scrams (while critical) last 12 months:	2
		Main Steam Safety and Relief Valve Challenges this month:	0