



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001  
AREA CODE 716-546-2700



November 10, 2000


US Nuclear Regulatory Commission  
Document Control Desk  
Attn: Guy S. Vissing  
Project Directorate I-1  
Washington, DC 20555

Subject: Monthly Report for October, 2000  
Operating Status Information  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of October, 2000.

Very truly yours,

  
Joseph A. Widay  
Plant Manager

xc: U.S. Nuclear Regulatory Commission  
Mr. Guy S. Vissing (Mail Stop 8C2)  
Project Directorate I-1  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

TE24

# OPERATING DATA REPORT

-1-

50-244

November 10, 2000

COMPLETED BY: John V. Walden

John V. Walden

TELEPHONE (716) 771-3588

## OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT Notes:
2. Reporting Period: October, 2000
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

	This Month	Yr.-to-Date	Cumulative**
5. Number of hours Reactor Was Critical	<u>316.2</u>	<u>6584.3</u>	<u>220798.2</u>
6. Hours Generator On-line	<u>287.4</u>	<u>6538.2</u>	<u>217682.1</u>
7. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
8. Net Electrical Energy Generated (MWH)	<u>113416.8</u>	<u>3088543.4</u>	<u>98473678.8</u>

\* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

\*\* CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244  
 UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT  
 DATE: November 10, 2000  
 COMPLETED BY: John V. Walden  
 TELEPHONE: (716) 771-3588

**UNIT SHUTDOWN**

**REPORTING PERIOD:** October, 2000  
 (Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON <sup>(1)</sup>	METHOD OF SHUTTING DOWN <sup>(2)</sup>	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
2	000918	S	435.4	C	1	
3	001021	F	22.2	A	2	Manual trip of Reactor and Turbine due to trip of "B" Circulating Water pump.

**SUMMARY:**

The refueling shutdown which began on September 18, 2000 was completed on October 19, 2000 at 0324 hours. Power ascension following the outage progressed until 0600 on October 21, 2000 when power was held at 70% for off-site circuit work. A manual reactor trip occurred on October 21, 2000 at 1420 hours due to the trip of the "B" Circulating Water pump. The unit was placed on-line at 1231 on October 22, 2000. Full power was attained on October 24, 2000 at 2120. The unit operated at full power for the remainder of the month of October.

**(1) Reason**

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

**(2) Method**

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)