

ENERGY NORTHWEST

P.O. Box 968 ■ Richland, Washington 99352-0968

October 10, 2000
GO2-00-191

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Gentlemen:

Subject: **WNP-2 OPERATING LICENSE NPF-21
MONTHLY OPERATING REPORT
OCTOBER 2000**

Transmitted herewith is the Monthly Operating Report for the month of October 2000 as required by Technical Specification 5.6.4.

Respectfully,



G.O. Smith
Vice President, Generation
Mail Drop 927M

cc: EW Merschoff - NRC RIV
JS Cushing - NRR
NRC Sr. Resident Inspector - 927N
TC Poindexter - Winston & Strawn
INPO
ANI Library
Utility Data Institute
DL Williams - BPA / 1399

IE24

OPERATING STATUS REPORT
for WNP-2

Date: November 1, 2000

- | | | | | |
|-----|--|---------|-----------|------------|
| 1. | Docket: 50-397 | | | |
| 2. | Reporting Period: October 2000 | | | |
| 3. | Utility Contact: Bernice Kasko (509) 377-4473 | | | |
| 4. | Design Electrical Rating (Net MW _e): | | | 1153 |
| 5. | Maximum Dependable Capacity - summer (Net MW _e): | | | 1107 |
| | | MONTH | YEAR | CUMULATIVE |
| 6. | Hours Reactor Critical | 745.0 | 6,996.9 | 101,972.3 |
| 7. | Hours Generator On-Line | 745.0 | 6,922.1 | 98,815.9 |
| 8. | Unit Reserve Shutdown Hours | 0.0 | 0.0 | 3,274.7 |
| 9. | Net Electrical Energy (MWH) | 837,761 | 6,949,789 | 96,365,613 |
| 10. | Challenges to safety/relief valves: | | | None |

UNIT SHUTDOWNS

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: November 1, 2000
COMPLETED BY: B Kasko
TELEPHONE: (509) 377-4473

REPORT PERIOD: October, 2000

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method (2)	Cause and Corrective Action To Prevent Recurrence
N/A						

SUMMARY: The plant ended the month at full power operation

(1) REASON

- | | |
|----------------------------|---|
| A - Equipment Failure | E - Operator Training & License Examination |
| B - Maintenance or Test | F - Administration |
| C - Refueling | G - Operational Error |
| D - Regulatory Restriction | H - Other |

(2) METHOD

- 1 - Manual
- 2 - Manual Scram
- 3 - Auto Scram
- 4 - Continued
- 5 - Reduced Load
- 9 - Other