



**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

November 17, 2000

Docket No. 50-443

NYN-00097

United States Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555

Seabrook Station
Steam Generator Tubes Plugged During Seventh Inservice Inspection

North Atlantic Energy Service Corporation (North Atlantic) has enclosed, pursuant to Seabrook Station Technical Specification Surveillance Requirement 4.4.5.5a, a tabulation of the number of tubes plugged in each of two steam generators ("B" and "C") inspected during the Seventh inservice inspection. The Seventh inservice inspection was completed on November 9, 2000.

The complete results of the Seventh inservice inspection for steam generators "B" and "C" will be submitted prior to November 9, 2001, pursuant to Technical Specification Surveillance Requirement 4.4.5.5b.

Should you have any questions regarding this information, please contact Mr. James M. Peschel, Manager-Regulatory Programs at (603) 773-7194.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.

Ted C. Feigenbaum
Executive Vice President and
Chief Nuclear Officer

cc: H. J. Miller, Regional Administrator
R. M. Pulsifer, NRC Project Manager, Project Directorate 1-2
R. K. Lorson, NRC Senior Resident Inspector

A047

ENCLOSURE 1 TO NYN-00097

Seabrook Station

Steam Generator Tubes Plugged During Seventh Inservice Inspection

<u>S/G</u>	<u>Row</u>	<u>Column</u>	<u>Indication</u>	<u>Reason</u>	<u>Comment</u>
B	40	38	39%	AVB	Preventive
B	30	51	40%	AVB	
B	39	53	50%	AVB	
B	28	55	40%	AVB	
B	30	70	37%	AVB	Preventive w/dent
B	41	74	48%	AVB	
B	53	87	39%	AVB	Preventive
C	1	11		Volumetric	Below Baffle plate
C	39	17	43%	AVB	
C	43	28		Volumetric	Top of Tube Sheet
C	44	28		PLP	Preventive
C	48	34	57%	AVB	
C	47	42	43%	AVB	
C	51	71	39%	AVB	Preventive
C	49	96	40%	AVB	
C	41	98	41%	AVB	