

May 15, 1989

Docket No. 50-334

Mr. J. D. Sieber, Vice President
Nuclear Group
Duquesne Light Company
Post Office Box 4
Shippingport, PA 15077

DISTRIBUTION

Docket File	DHagan
NRC & Local PDRs	EJordan
Plant File	BGrimes
SVarga	TMeek (4)
BBoger	WJones
SNorris	EButcher
PTam	ARM/LFMB GPA/PA
OGC	ACRS(10)

Dear Mr. Sieber:

SUBJECT: BEAVER VALLEY UNIT 1 - CORRECTION OF ERROR IN AMENDMENT NO. 138
(TAC 66618)

When we issued Amendment No. 138 on April 3, 1989, we inadvertently used a technical specification page that predated Amendment No. 120. As a result, the page we issued did not include Amendment No. 120 changes.

Enclosed is a corrected page 3/4 3-27. We apologize for any inconvenience this may have caused.

Sincerely,

Signed by

Peter S. Tam, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

[DOCKET NO. 50-334]

LA:PDI-4
SNorris
5/15/89

PM:PDI-4
PTam:cb
5/15/89

PD:PDI-4
JStolz
5/15/89

JFol

CP

8905190457 890515
PDR ADOCK 05000334
P PDC

DISTRIBUTION

Docket File
NRC & Local PDRs
SVarga
BBoger
SNorris
PTam
OGC
DHagan
EJordan
BGrimes
TMeek (4)
WJones
ACRS(10)
GPA/PA
ARM/LFMB

Mr. J. Sieber
Duquesne Light Company

Beaver Valley Power Station
Units 1 & 2

cc:

Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
ATTN: R. Janati
Post Office Box 2063
Harrisburg, Pennsylvania 17120

Kenny Grada, Manager
Nuclear Safety
Duquesne Light Company
P. O. Box 4
Shippingport, Pennsylvania 15077

Mayor of the Borough of
Shippingport
Post Office Box 3
Shippingport, Pennsylvania 15077

John A. Lee, Esquire
Duquesne Light Company
One Oxford Centre
301 Grant Street
Pittsburgh, Pennsylvania 15279

Ashley C. Schannauer
Assistant City Solicitor
City of Pittsburgh
313 City-County Building
Pittsburgh, Pennsylvania 15219

W.F. Carmichael, Commissioner
Department of Labor
1800 Washington Street East
Charleston, West Virginia 25305

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

John D. Borrows
Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 181
Shippingport, Pennsylvania 15077

Director, Pennsylvania Emergency
Management Agency
Post Office Box 3321
Harrisburg, Pennsylvania 17105-3321

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
4. <u>Steam Line Pressure-Low</u>	
a. Safety Injection (ECCS)	≤ 27.0#/37.0##
b. Reactor Trip (from SI)	≤ 3.0
c. Feedwater Isolation	≤ 75.0(1)
d. Containment Isolation-Phase "A"	≤ 22.0(3)/33.0(2)
e. Auxiliary Feedwater Pumps	Not Applicable
f. Rx Plant River Water System	≤ 77.0(3)/110.0(2)
g. Steam Line Isolation	≤ 8.0
5. <u>Containment Pressure--High-High</u>	
a. Containment Quench Spray	≤ 77.0
b. Containment Isolation-Phase "B"	Not Applicable
c. Control Room Ventilation Isolation	≤ 22.0(3)/77.0(2)
6. <u>Steam Generator Water Level--High-High</u>	
a. Turbine Trip-Reactor Trip (Above P-9)	≤ 2.5
b. Feedwater Isolation	≤ 13.0(2)
7. <u>Containment Pressure--Intermediate High-High</u>	
a. Steam Line Isolation	≤ 8.0
8. <u>Steamline Pressure Rate--High Negative</u>	
a. Steamline Isolation	≤ 8.0
9. <u>Loss of Power</u>	
a. 4.16kv Emergency Bus Undervoltage (Loss of Voltage)	≤ 1.3
b. 4.16kv and 480v Emergency Bus Under- voltage (Degraded Voltage)	≤ 95

BEAVER VALLEY - UNIT 1

3/4 3-27

Amendment No. ~~40, 112, 120,~~
138
Correction letter dated
5/15/89