

## REFUELING OPERATIONS

### BORON CONCENTRATION

#### LIMITING CONDITION FOR OPERATION

---

---

3.9.1.2 The soluble boron concentration of the Spent Fuel Pool shall be maintained uniform, and greater than or equal to 800 ppm. |

#### Applicability

Whenever fuel assemblies are in the spent fuel pool.

#### Action

- a. With the boron concentration less than 800 ppm, initiate action to bring the boron concentration in the fuel pool to at least 800 ppm within 72 hours, and |
- b. With the boron concentration less than 800 ppm, suspend the movement of all fuel assemblies within the spent fuel pool and loads over the spent fuel racks. |

#### SURVEILLANCE REQUIREMENTS

---

---

4.9.1.2 Verify that the boron concentration in the fuel pool is greater than or equal to 800 ppm every 7 days. |