

December 5, 2000

LICENSEE: Calvert Cliffs Nuclear Power Plant, Inc.

FACILITY: Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF NOVEMBER 1, 2000, MEETING REGARDING CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 RE: STEAM GENERATOR REPLACEMENT PROJECT (TAC NOS. MB0061 AND MB0062)

On November 1, 2000, the Nuclear Regulatory Commission (NRC) and Calvert Cliffs Nuclear Power Plant, Inc. (CCNPPI) and their contractor, Steam Generator Team (SGT), held a meeting in One White Flint North, Rockville, Maryland, to discuss the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2 steam generator (SG) replacement project, including the use of the Gothic Code. Enclosure 1 is a list of attendees. Enclosure 2 and 3 are copies of the viewgraphs distributed at the meeting. Enclosure 2 viewgraphs are related to the licensee's safety evaluation review of the SG replacement and Enclosure 3 are viewgraphs related to the use of the GOTHIC Code in the containment analysis made necessary by the SG replacement.

The purpose of the meeting was for CCNPPI to present status of their Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2 SG replacement.

The licensee discussed the status of license activities. CCNPPI presented engineering and construction status of the replacement generators. CCNPPI also discussed pre-service inspection of the SG tubes and pressure tests performed on the SG.

The licensee presented a detailed discussion on the safety evaluation relative to the replacement SG. In its discussion, the most significant design/operation changes and the philosophy used to review each of the design basis transients and accidents were addressed. The NRC staff does not have any outstanding issues regarding the licensee's presentation.

The staff requested that the licensee ensure that the changes being made to the SG pressure boundary that are also part of the containment boundary meet the requirements of 10 CFR Part 50, Appendix J, for leak-rate testing. No issues were identified by the staff in the area of containment accident analysis.

Sincerely,

/RA/

Alexander W. Dromerick, Sr. Project Manager, Section I
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-518

Enclosures: As stated

cc w/encls: See next page

LICENSEE: Calvert Cliffs Nuclear Power Plant, Inc.

December 5, 2000

FACILITY: Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF NOVEMBER 1, 2000, MEETING REGARDING CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 RE: STEAM GENERATOR REPLACEMENT PROJECT (TAC NOS. MB0061 AND MB0062)

On November 1, 2000, the Nuclear Regulatory Commission (NRC) and Calvert Cliffs Nuclear Power Plant, Inc. (CCNPPI) and their contractor, Steam Generator Team (SGT), held a meeting in One White Flint North, Rockville, Maryland, to discuss the Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2 steam generator (SG) replacement project, including the use of the Gothic Code. Enclosure 1 is a list of attendees. Enclosure 2 and 3 are copies of the viewgraphs distributed at the meeting. Enclosure 2 viewgraphs are related to the licensee's safety evaluation review of the SG replacement and Enclosure 3 are viewgraphs related to the use of the GOTHIC Code in the containment analysis made necessary by the SG replacement.

The purpose of the meeting was for CCNPPI to present status of their Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2 SG replacement.

The licensee discussed the status of license activities. CCNPPI presented engineering and construction status of the replacement generators. CCNPPI also discussed pre-service inspection of the SG tubes and pressure tests performed on the SG.

The licensee presented a detailed discussion on the safety evaluation relative to the replacement SG. In its discussion, the most significant design/operation changes and the philosophy used to review each of the design basis transients and accidents were addressed. The NRC staff does not have any outstanding issues regarding the licensee's presentation.

The staff requested that the licensee ensure that the changes being made to the SG pressure boundary that are also part of the containment boundary meet the requirements of 10 CFR Part 50, Appendix J, for leak-rate testing. No issues were identified by the staff in the area of containment accident analysis.

Sincerely,

/RA/

Alexander W. Dromerick, Sr. Project Manager, Section I
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-518

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	M. Gamberoni (hard copy)	R. Lobel
PDI-1 Reading File	S. Little	C. Liang
A. Dromerick	A. Drozd	J. Lehning
OGC	E. Throm	J. Shea
ACRS	H. Gray	B. Platchek. RI
J. Zwolinski/S. Black	D. Jeng	
E. Adensam	J. Tsao	

Accession Number: (G:\PDI-1\MeetingSummaryNov1.wpd) ML003773346

OFFICE	PM:PDI-1	LA:PDI-1	SC:PDI-1
NAME	ADromerick	SLittle	MGamberoni
DATE	11/30/00	11/30/00	11/30/00

LIST OF ATTENDEES

CALVERT CLIFFS NUCLEAR POWER PLANT, INC.

NOVEMBER 1, 2000

<u>NAME</u>	<u>ORGANIZATION</u>
Alex Dromerick	NRC/NRR/DLPM
Andre Drozd	NRC/NRR/DSSA
Edward D. Throm	NRC/NRR/DSSA/SPSB
Harold Gray	NRC/REGION I - DRS
Thomas Konerth	CCNPPI
Mary Beth Baker	FTI
Mark Finley	CCNPPI
Mahmoad Massoud	CCNPPI
Jeff Millman	B&W Canada
Mark Ceraldi	SGT/Licensing Engineer
Kevin Connell	SGT/Procurement Manager
William C. Holston	CCNPPI
David C. Jeng	NRC/NRR/DE/EMEB
John Tsao	NRC/NRR/DE/EMCB
Getachew Tesfaye	CCNPPI
Richard Lobel	NRC/NRR/DSSA/SPLB
Chu-yu Liang	NRC/NRR/DSSA/SRXB
John Lehning, III	NRC/NRR/DSSA/SPLB
Allen Norafrancesco	RES/DSARE/SMSAB

Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 and 2

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

James P. Bennett, Esquire
Counsel
Constellation Energy Group
P.O. Box 1475
Baltimore, MD 21203

Jay E. Silberg, Esquire
Shaw, Pittman, Potts, and Trowbridge
2300 N Street, NW
Washington, DC 20037

Mr. Bruce S. Montgomery, Director
NRM
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory
Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. Richard I. McLean, Manager
Nuclear Programs
Power Plant Research Program
Maryland Dept. of Natural Resources
Tawes State Office Building, B3
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Joseph H. Walter, Chief Engineer
Public Service Commission of
Maryland
Engineering Division
6 St. Paul Centre
Baltimore, MD 21202-6806

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218

Mr. Loren F. Donatell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Mr. Charles H. Cruse
Vice President, Nuclear Energy
Calvert Cliffs Nuclear Power Plant, Inc.
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657