

May 4, 1987

MEMORANDUM FOR: Sholly Coordinator DISTRIBUTION
Docket File
FROM: Robert A. Capra, Acting Director J. Scinto
Project Directorate I-1 NRC PDR
Division of Reactor Projects, I/II PDI-1 Rdg.
C. Vogan
S. McNeil
SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSES

Baltimore Gas & Electric Company, Docket No. 50-318, Calvert Cliffs Nuclear
Power Plant, Unit No. 2, Calvert County, Maryland

Date of application for amendment: February 6, 1987, as supplemented March 17,
March 25, March 27, April 7, and April 17, 1987.

Brief description of amendment: The amendment changes the Unit 2 Technical
Specifications (TS) to reflect analyses performed in support of Unit 2
Cycle 8 operation by providing more restrictive limits for the Acceptable
Operation Region of peripheral axial shape index versus rate thermal power
and for shutdown margin while also raising the moderator temperature coefficient
limit for operation above 70% power.

The supplements to the February 6, 1987 submittal did not affect the
proposed TS changes noticed in the Federal Register on March 25, 1987 and
did not affect the staff's proposed no significant hazards determination.

Date of issuance: May 4, 1987

Effective date: May 4, 1987

Amendment No.: 108

Facility Operating License No. DPR-48. Amendment revised the Technical
Specifications.

Date of initial notice in Federal Register: March 25, 1987 (52 FR 9560)

The Commission's related evaluation of the amendment is contained in a
Safety Evaluation dated May 4, 1987.

8705070207 870504
PDR ADCK 05000318
P PDR

No significant hazards consideration comments received: No

Local Public Document Room location: Calvert County Library, Prince
Frederick, Maryland.

Robert A. Capra, Acting Director
Project Directorate I-1
Division of Reactor Projects, I/II

PDI-1 *W*
CVogan
4/23/87

PDI-1
SMcNe *SM*
4/23/87

OGC
Fullerhead
4/30/87

Rae
PDI-1
RCapra
5/4/87