



November 21, 2000  
LR-E00-0462

New Jersey Department of  
Environmental Protection  
Division of Water Quality  
Bureau of Permit Management  
P.O. Box 029  
Trenton, NJ 08625-0029  
Certified Mail Number 7099 3400 0003 6394 5291

**NEW JERSEY POLLUTANT DISCHARGE ELIMINATION SYSTEM  
DISCHARGE MONITORING REPORTS  
SALEM GENERATING STATION  
PERMIT NO. NJ0005622**

Attached is the Discharge Monitoring Report for Salem Generating Station containing the information as required in Permit No. NJ0005622, for the month of October 2000.

This report is required by and prepared specifically for the Environmental Protection Agency (EPA) and the New Jersey Department of Environmental Protection (NJDEP). It presents only the observed results of measurements and analyses required to be performed by the above agencies. The choice of the measurement devices and analytical methods is controlled by EPA and NJDEP, not by the company, and there are limitations on the accuracy of such measurement devices and analytical techniques even when used and maintained as required. Accordingly, this report is not intended as an assertion that any instrument has measured, or any reading or analytical result represents, the true value with absolute accuracy, nor is it an endorsement of the suitability of any analytical or measurement procedure.

Sincerely,

A handwritten signature in black ink, appearing to read "Mark B. Bezilla".

Mark B. Bezilla  
Vice President Operations

Attachments

Handwritten initials "JE25" in black ink, located in the bottom right corner of the page.

NJPDES Report  
October 2000

- C     Executive Director – DRBC  
       USNRC – Document Control Desk Unit#1-50-272 Unit#2-50-311  
       Vice President Operations  
       Licensing Manager  
       M. Vaskis  
       D. Hurka  
       J. Schloss  
       Central Record Facility  
       E. Keating

NJPDES Report  
Explanation of Deviations  
October 2000

The following excursions are included in the attached report and are explained below. Excursions have not endangered nor significantly impacted public health or the environment.

<u>DSN NO.</u>	<u>EXPLANATION</u>
	None

COUNTY OF SALEM  
STATE OF NEW JERSEY


I, Mark B. Bezilla, of full age, being duly sworn according to law, upon my oath depose and say:

1. I am the Vice President, Operations for PSEG Nuclear, and as such, am authorized to sign Salem's Discharge Monitoring Reports submitted to the New Jersey Department of Environmental Protection pursuant to the Station's New Jersey Pollutant Discharge Elimination System permit.
2. I have reviewed the attached Discharge Monitoring Reports. Pursuant to N.J. A. C. 7:14A-2.4, I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that based on my inquiry of those individuals responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.
3. The signature on the attached Discharge Monitoring Reports is my signature and I am submitting this affidavit in satisfaction of the requirement that my signature be notarized.



Mark B. Bezilla  
Vice President  
Operations

Sworn and subscribed before me  
this 2 day of NOV 2000



SHERI L. HUSTON  
NOTARY PUBLIC OF NEW JERSEY  
My Commission Expires 12/08/2003

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge A**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **FACA SW Outfall FACA**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:

**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:

**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000

AREA CODE / TELEPHONE NUMBER

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACA SW Outfall FACA

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****	25.9	28.8		0	Continuous	Contin
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	43.3 01DAMX	DEG.C		Continuous	CONTIN
Temperature, oC 00010 2 Effluent Net Value	SAMPLE MEASUREMENT	*****	*****		*****	8.1	9.4		0	Continuous	Calctd
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	15.3 01DAMX	DEG.C		Continuous	CALCTD
Temperature, oC 00010 G Raw Sew/influent	SAMPLE MEASUREMENT	*****	*****		*****	17.8	20.6		0	Continuous	Contin
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	REPORT 01DAMX	DEG.C		Continuous	CONTIN
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		46405	77343					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **FACB SW Outfall FACB**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:  
**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:  
**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operation

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856) 935-6000

*11/21/00*

AREA CODE / TELEPHONE NUMBER

DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACB SW Outfall FACB

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	22.3	29.0	DEG.C	0	Continuous	CONTIN
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	43.3 01DAMX			Continuous	CONTIN
Temperature, oC 00010 2 Effluent Net Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	4.5	8.4	DEG.C	0	Continuous	CALCTD
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	15.3 01DAMX			Continuous	CALCTD
Temperature, oC 00010 G Raw Sew/influent	SAMPLE MEASUREMENT	*****	*****	*****	*****	17.8	20.6	DEG.C	0	Continuous	CONTIN
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	REPORT 01DAMX			Continuous	CONTIN
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		46405	77343				Not Applic	NOT AP
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: NJ0005622  
MONITORING REPORT TYPE: Surface Water Discharge A  
MONITORING PERIOD: 10/1/2000 - 10/31/2000

MONITORED LOCATION: FACC SW Outfall FACC  
MONITORED LOCATION GROUP: N/A  
REGION / COUNTY: Southern / Salem County

PERMITTEE NAME AND ADDRESS:

PSE&G  
PO BOX 236/N21  
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G GENERATING STA (SALEM)  
ALLOWAY CREEK NECK RD  
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE:  No Discharge this Monitoring Period

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856) 935-6000

AREA CODE / TELEPHONE NUMBER

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

FACC SW Outfall FACC

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER	X	QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 G Raw Sew/influent	SAMPLE MEASUREMENT	1684	2761	MGD	*****	*****	*****	*****	0	1/Day <sup>with</sup> <del>Continuous</del>	CALCTD
	PERMIT REQUIREMENT	3024 01MOAV	REPORT 01DAMX		*****	*****	*****			*****	1/Day
Thermal Discharge Million BTUs per Hr 00015 2 Effluent Net Value	SAMPLE MEASUREMENT	8265	13368	MBTU/HR	*****	*****	*****	*****	0	Continuous	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	30600 01DAMX		*****	*****	*****			*****	Continuous
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		46405	77343				Not Applic	NOT AP
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge A**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **048C SW Outfall 48C**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:

**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:

**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856) 935-6000

AREA CODE / TELEPHONE NUMBER

DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

048C SW Outfall 48C

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	0.1566	0.3739	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****			*****	1/Day
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	10	12	MG/L	0	2/Month	COMPOS
	PERMIT REQUIREMENT	*****	*****		*****	30 01MOAV	100 01DAMX			2/Month	COMPOS
Nitrogen, Ammonia Total (as N) 00610 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	3	3	MG/L	0	2/Month	COMPOS
	PERMIT REQUIREMENT	*****	*****		*****	35 01MOAV	70 01DAMX			2/Month	COMPOS
Hydrocarbons, in H2O, IR, CCl4 Ext. Chrom. 00551 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.5	<0.5	MG/L	0	2/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX			2/Month	GRAB
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	14	20	MG/L	0	2/Month	COMPOS
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX			2/Month	COMPOS
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		46405	77343					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4680 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge A**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **481A SW Outfall 481A**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:  
**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:  
**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**


CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations  
NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000  
AREA CODE / TELEPHONE NUMBER

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

481A SW Outfall 481A

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER	X SAMPLE MEASUREMENT	QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1		475	530	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
Effluent Gross Value	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****				
pH 00400 1	SAMPLE MEASUREMENT	*****	*****	*****	7.5	*****	7.8	SU	0	1/Week	GRAB
Effluent Gross Value	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX				
pH 00400 7	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.0	SU	0	1/Week	GRAB
Intake From Stream	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX				
LC50 Fthd Minnow Static Defn TA1CA 1	SAMPLE MEASUREMENT	*****	*****	*****	CODE=N	*****	*****	%EFFL	0	1/Quarter	CODE=N COMPOS
Effluent Gross Value	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****				
Chlorine, Total Residual 50060 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE=N	CODE=N	MG/L	0	3/Week	CODE=N GRAB
Effluent Gross Value Option 1	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX				
Chlorine, Total Residual 50060 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/Week	GRAB
Effluent Gross Value Option 2	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX				
Lab Certification # 99999 99	SAMPLE MEASUREMENT	17327	06431		46405	77343					
Lab	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #				

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "rosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: NJ0005622  
MONITORING REPORT TYPE: Surface Water Discharge A  
MONITORING PERIOD: 10/1/2000 - 10/31/2000

MONITORED LOCATION: 482A SW Outfall 482A  
MONITORED LOCATION GROUP: N/A  
REGION / COUNTY: Southern / Salem County

PERMITTEE NAME AND ADDRESS:

PSE&G  
PO BOX 236/N21  
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G GENERATING STA (SALEM)  
ALLOWAY CREEK NECK RD  
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE:  No Discharge this Monitoring Period

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark. B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000

AREA CODE / TELEPHONE NUMBER

DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

482A SW Outfall 482A

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	487	493	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Day	CALCTD
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.4	*****	7.8	SU	0	1/week	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX		1/Week	GRAB	
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.0	SU	0	1/week	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX		1/Week	GRAB	
LC50 Fthd Minnow Static Defn TA1CA 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	> 100	*****	*****	%EFFL	0	1/Quarter	COMPOS
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****		1/Quarter	COMPOS	
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE=N	CODE=N	MG/L	0	CODE=N	CODE=N
	PERMIT REQUIREMENT	*****	*****		0.3 01MOAV	0.5 01DAMX	3/Week		GRAB		
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01MOAV	0.2 01DAMX	3/Week		GRAB		
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431	*****	46405	77343	*****	*****	*****	*****	*****
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		Not Applic	NOT AP	

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "rosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge A**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **483A SW Outfall 483A**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:  
**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:  
**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations \_\_\_\_\_

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000 \_\_\_\_\_

AREA CODE / TELEPHONE NUMBER

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

483A SW Outfall 483A

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1	SAMPLE MEASUREMENT	458	471	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
Effluent Gross Value	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****		1/Day
pH 00400 1	SAMPLE MEASUREMENT	*****	*****	*****	7.5	*****	7.8	SU	0	1/week	GRAB
Effluent Gross Value	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX		*****		1/Week
pH 00400 7	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.0	SU	0	1/week	GRAB
Intake From Stream	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX		*****		1/Week
LC50 Fthd Minnow Static Defn TA1CA 1	SAMPLE MEASUREMENT	*****	*****	*****	CODE=N	*****	*****	%EFFL	0	CODE=N	CODE=N
Effluent Gross Value	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****		*****		1/Quarter
Chlorine, Total Residual 50060 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	CODE=N	CODE=N	MG/L	0	CODE=N	CODE=N
Effluent Gross Value Option 1	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX		*****		3/Week
Chlorine, Total Residual 50060 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
Effluent Gross Value Option 2	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX		*****		3/Week
Lab Certification # 99999 99	SAMPLE MEASUREMENT	17327	06431	*****	46405	77343		*****			
Lab	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		*****		Not Applic

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: NJ0005622  
MONITORING REPORT TYPE: Surface Water Discharge A  
MONITORING PERIOD: 10/1/2000 - 10/31/2000

MONITORED LOCATION: 484A SW Outfall 484A  
MONITORED LOCATION GROUP: N/A  
REGION / COUNTY: Southern / Salem County

PERMITTEE NAME AND ADDRESS:

PSE&G  
PO BOX 236/N21  
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:

PSE&G GENERATING STA (SALEM)  
ALLOWAY CREEK NECK RD  
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE:  No Discharge this Monitoring Period

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000

AREA CODE / TELEPHONE NUMBER

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

484A SW Outfall 484A

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	110	455	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****		1/Day
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.8	SU	0	1/week	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX		*****		1/Week
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.0	SU	0	1/week	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX		*****		1/Week
LC50 Fthd Minnow Static Defn TA1CA 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	CODE=N	*****	*****	%EFFL	0	CODE=N	CODE=N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****		*****		1/Quarter
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.1	0.2	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX		*****		3/Week
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX		*****		3/Week
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431	*****	46405	77343	*****	*****			
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		REPORT Lab #		Not Applic

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge A**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **485A SW Outfall 485A**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:

**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:

**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000

AREA CODE / TELEPHONE NUMBER

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

485A SW Outfall 485A

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	139	456	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Day	CALCTD
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.2	*****	7.8	SU	0	1/Week	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX		1/Week	GRAB	
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.0	SU	0	1/week	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX		1/Week	GRAB	
LC50 Fthd Minnow Static Defn TA1CA 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	CODE=N	*****	*****	%EFFL	0	CODE=N	CODE=N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****		1/Quarter	COMPOS	
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX		3/Week	GRAB	
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX		3/Week	GRAB	
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		46405	77343					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		Not Applic	NOT AP	

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: NJ0005622  
MONITORING REPORT TYPE: Surface Water Discharge A  
MONITORING PERIOD: 10/1/2000 - 10/31/2000

MONITORED LOCATION: 486A SW Outfall 486A  
MONITORED LOCATION GROUP: N/A  
REGION / COUNTY: Southern / Salem County

PERMITTEE NAME AND ADDRESS:  
PSE&G  
PO BOX 236/N21  
HANCOCKS BRIDGE, NJ 08038

LOCATION OF ACTIVITY:  
PSE&G GENERATING STA (SALEM)  
ALLOWAY CREEK NECK RD  
LOWER ALLOWAYS CREEK, NJ 08038-0000

CHECK IF APPLICABLE:  No Discharge this Monitoring Period

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based un my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000

AREA CODE / TELEPHONE NUMBER

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER: NJ0005622

MONITORED LOCATION: 486A SW Outfall 486A

MONITORING PERIOD: 10/1/2000 TO 10/31/2000

FACILITY NAME: PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	86	456	MGD	*****	*****	*****	*****	0	1/Day	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Day	CALCTD
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.7	SU	0	1/Week	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX		1/Week	GRAB	
pH 00400 7 Intake From Stream	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	8.0	SU	0	1/week	GRAB
	PERMIT REQUIREMENT	*****	*****		REPORT 01DAMN	*****	REPORT 01DAMX		1/Week	GRAB	
LC50 Fthd Minnow Static Defn TA1CA 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	CODE=N	*****	*****	%EFFL	0	CODE=N	CODE=N
	PERMIT REQUIREMENT	*****	*****		50 01DAMN	*****	*****		1/Quarter	COMPOS	
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 1	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	0.3 01MOAV	0.5 01DAMX		3/Week	GRAB	
Chlorine, Total Residual 50060 1 Effluent Gross Value Option 2	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	MG/L	0	3/week	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	0.2 01DAMX		3/Week	GRAB	
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431		46405	77343					
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		REPORT Lab #	Not Applic	NOT AP

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "rosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge A**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **489A SW Outfall 489A**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:

**PSE&G  
PO BOX 236/N21  
HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:

**PSE&G GENERATING STA (SALEM)  
ALLOWAY CREEK NECK RD  
LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

\_\_\_\_\_(856)935-6000\_\_\_\_\_  
AREA CODE / TELEPHONE NUMBER

11/22/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

489A SW Outfall 489A

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT	0.0832	0.0832	MGD	*****	*****	*****	*****	0	1/Month	CALCTD
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX		*****	*****	*****		*****	1/Month	CALCTD
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	7.7	*****	7.7	SU	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		6.0 01DAMN	*****	9.0 01DAMX		1/Month	GRAB	
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	5	5	5	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		100 01DAMX	30 01MOAV	45 01WKAV		1/Month	GRAB	
Hydrocarbons, in H2O, IR, CCl4 Ext. Chrom. 00551 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.5	<0.5	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	10 01MOAV	15 01DAMX		1/Month	GRAB	
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****	*****	*****	8	8	MG/L	0	1/Month	GRAB
	PERMIT REQUIREMENT	*****	*****		*****	REPORT 01MOAV	50 01DAMX		1/Month	GRAB	
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT	17327	06431	*****	46405	77343		*****			
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #		REPORT Lab #	Not Applic	NOT AP

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".

New Jersey Department of Environmental Protection  
Division of Water Quality

**MONITORING REPORT SUBMITTAL FORM**

NJPDES PERMIT NUMBER: **NJ0005622**  
MONITORING REPORT TYPE: **Surface Water Discharge N**  
MONITORING PERIOD: **10/1/2000 - 10/31/2000**

MONITORED LOCATION: **487B SW Outfall 487B**  
MONITORED LOCATION GROUP: **N/A**  
REGION / COUNTY: **Southern / Salem County**

PERMITTEE NAME AND ADDRESS:  
**PSE&G**  
**PO BOX 236/N21**  
**HANCOCKS BRIDGE, NJ 08038**

LOCATION OF ACTIVITY:  
**PSE&G GENERATING STA (SALEM)**  
**ALLOWAY CREEK NECK RD**  
**LOWER ALLOWAYS CREEK, NJ 08038-0000**

CHECK IF APPLICABLE:  **No Discharge this Monitoring Period**

MONITORING REPORT COMMENTS:

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. § 1319.

*(Penalties under these statutes may include fines up to \$10,000 and or a maximum imprisonment of between 6 months and 5 years.)*

Mark B. Bezilla Vice President Operations

NAME AND TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

  
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

(856)935-6000  
AREA CODE / TELEPHONE NUMBER

11/24/00  
DATE (MONTH / DAY / YEAR)

# Surface Water Discharge Monitoring Report

PERMIT NUMBER:

MONITORED LOCATION:

MONITORING PERIOD:

FACILITY NAME:

NJ0005622

487B SW Outfall 487B

10/1/2000 TO 10/31/2000

PSE&G GENERATING STA (SALEM)

PARAMETER		QUANTITY OR LOADING		UNITS	QUANTITY OR CONCENTRATION			UNITS	NO. EX.	FREQ. OF ANALYSIS	SAMPLE TYPE
Flow, In Conduit or Thru Treatment Plant 50050 1 Effluent Gross Value	SAMPLE MEASUREMENT				*****	*****	*****				
	PERMIT REQUIREMENT	REPORT 01MOAV	REPORT 01DAMX	MGD	*****	*****	*****	*****		1/Batch	CALCTD
pH 00400 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****			*****					
	PERMIT REQUIREMENT	*****	*****	*****	6.0 01DAMN	*****	9.0 01DAMX	SU		1/Batch	GRAB
Solids, Total Suspended 00530 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	100 01DAMX	MG/L		1/Batch	GRAB
Temperature, oC 00010 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	43.3 01DAMX	DEG.C		1/Batch	GRAB
Hydrocarbons, in H2O, IR, CCl4 Ext. Chrom. 00551 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	15 01DAMX	MG/L		1/Batch	GRAB
Carbon, Tot Organic (TOC) 00680 1 Effluent Gross Value	SAMPLE MEASUREMENT	*****	*****		*****						
	PERMIT REQUIREMENT	*****	*****	*****	*****	REPORT 01MOAV	50 01DAMX	MG/L		1/Batch	GRAB
Lab Certification # 99999 99 Lab	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT	REPORT Lab #	REPORT Lab #		REPORT Lab #	REPORT Lab #	REPORT Lab #			Not Applic	NOT AP

Comments: Your monitoring report forms have been converted to the Department's new NJ Environmental Management System (NJEMS). If there are any questions in regards to the monitoring report form, please contact Susan Rosenwinkel of the BPSP - Region 2 at (609)292-4860 or via email at "srosenwi@dep.state.nj.us".